

CIVIL ENGINEERING STANDARD METHOD OF MEASUREMENT

THE INSTITUTION OF CIVIL ENGINEERS

CESMM3

CIVIL ENGINEERING

STANDARD METHOD OF MEASUREMENT

THIRD EDITION



THOMAS TELFORD, LONDON, 1991

PREFACE

The *Civil Engineering Standard Method of Measurement*, third edition (CESMM3), has been approved by the sponsors—the Institution of Civil Engineers and the Federation of Civil Engineering Contractors—for use in works of civil engineering construction. This third edition supersedes the second edition published in 1985.

Reference to CESMM3 in the Appendix to the Form of Tender, as provided for by clause 57 of the ICE Conditions of Contract, sixth edition (January 1991) is sufficient to give effect to the use of this standard method of measurement for a particular contract.

CESMM3 may be used with other conditions of contract such as the ICE Conditions of Contract for Ground Investigation and the ICE Conditions of Contract for Minor Works. When other conditions of contract are used, paragraph 1.2 and clause numbers referred to in CESMM3 should be amended by a statement in the Preamble in accordance with paragraph 5.4.

The Committee under whose guidance CESMM3 has been prepared will keep the use of the document under review and consider any suggestions for amendment. These should be addressed to The Secretary, The Institution of Civil Engineers, 1-7 Great George Street, London SW1P 3AA. Revision of the document will be made when such action seems warranted.

First edition 1976
Second edition 1985
Third edition 1991
Reprinted with corrections 1992, 1995

IMPORTANT NOTE

Since CESMM3 was published in 1991, several errors have been identified and the opportunity has been taken to correct these errors in this reprint. For ease of reference the changes between this second printing and the first printing are given below.

Page	Reference	Change
6	3.2	In lines 4 and 5 the words 'plain round mild steel bar' have replaced 'mild steel bar'.
6	3.3	In line 3 the same change as above has been made.
11	5.18	The word 'CESMM3' has replaced 'the CESMM'.
17	Additional Description Rule A1	The term 'Certificate of Substantial Completion' has been inserted in rule 'A1'.
23	Additional Description Rule A12	The word 'and' has been inserted between 'pits' and 'trenches' in place of the comma.
73	Measurement Rule M11	A new rule 'M11' has been inserted and the previous rule 'M11' has become rule 'M12'.
76	Reference R6+8	The number '5' has been inserted in front of 'Transitions' in the Third Division.
77	Coverage Rule C4	The reference to rule 'M10' has replaced the reference to rule 'M9'.
89	Additional Description Rule A2	A comma which previously appeared after 'masonry' has been deleted.
103	Additional Description Rule A4	A bracket has been inserted after 'trusses' and a bracket which appeared after 'joinery' has been deleted.
107	Definition Rule D8	The word 'pipe' has been inserted in front of 'fittings'.
107	Note at foot of page	The note has been extended with the wording beginning 'provided that...'

© The Institution of Civil Engineers and The Federation of Civil Engineering Contractors, 1991

British Library Cataloguing in Publication Data
Civil engineering standard method of measurement,
—3rd ed.
I. Civil engineering—Measurement—Standards
I. Institution of Civil Engineers
624.0297 TA153

ISBN: 0 7277 1561 6

All rights, including translation, reserved. Except for fair copying, no part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means electronic, mechanical, photocopying, recording or otherwise, without prior written permission being obtained from the publisher.

Whilst every care has been taken in the preparation of this document neither the Institution nor the Federation of Civil Engineering Contractors nor any of their committees can accept any liability for any loss or damage which may be suffered by any person or organisation as a result of its use.

Printed and bound in Great Britain by William Clowes Limited, Beccles and London

CONTENTS

Foreword to the first edition	1
Foreword to the second edition	2
Foreword to the third edition	3
Section 1. Definitions	4
Section 2. General principles	5
Section 3. Application of the Work Classification	6
Section 4. Coding and numbering of items	8
Section 5. Preparation of the Bill of Quantities	9
Section 6. Completion, pricing and use of the Bill of Quantities	13
Section 7. Method-Related Charges	14
Section 8. Work Classification	15
Class A: General items, 16	
Class B: Ground investigation, 20	
Class C: Geotechnical and other specialist processes, 28	
Class D: Demolition and site clearance, 32	
Class E: Earthworks, 34	
Class F: In situ concrete, 40	
Class G: Concrete ancillaries, 42	
Class H: Precast concrete, 46	
Class I: Pipework—pipes, 48	
Class J: Pipework—fittings and valves, 50	
Class K: Pipework—manholes and pipework ancillaries, 52	
Class L: Pipework—supports and protection, ancillaries to laying and excavation, 56	
Class M: Structural metalwork, 60	
Class N: Miscellaneous metalwork, 62	
Class O: Timber, 64	
Class P: Piles, 66	
Class Q: Piling ancillaries, 70	
Class R: Roads and pavings, 74	
Class S: Rail track, 78	
Class T: Tunnels, 82	
Class U: Brickwork, blockwork and masonry, 88	
Class V: Painting, 90	
Class W: Waterproofing, 92	
Class X: Miscellaneous work, 94	
Class Y: Sewer and water main renovation and ancillary works, 96	
Class Z: Simple building works incidental to civil engineering works, 102	

FOREWORD TO THE FIRST EDITION

In 1964 the Council of the Institution of Civil Engineers set up a Committee under the Chairmanship of T. A. L. (now Sir Angus) Paton, CMG, BSc(Eng), FICE, to propose revisions to the *Standard Method of Measurement of Civil Engineering Quantities*. In 1971 the work of revision was undertaken by Martin Barnes, PhD, BSc(Eng), MICE, who worked initially under an agreement with the University of Manchester Institute of Science and Technology and, after he left the University in 1972, under a direct agreement with the Institution of Civil Engineers. A Steering Committee was appointed by the Council of the Institution of Civil Engineers to supervise the work. The Steering Committee was enlarged in 1972 by the appointment of an additional representative from each of the Institution of Civil Engineers, the Association of Consulting Engineers and the Federation of Civil Engineering Contractors. The members of the committee (* indicates member appointed in 1971) were

*D. C. Coode, FICE, FIEAust, Chairman

*M. Agar, BSc, FICE, FISTructE, Institution of Civil Engineers

F. J. Cava, BSc, FICE, FRICS, MTPI, FIMunE, FRSH, Institution of Civil Engineers

*H. R. Oakley, MSc(Eng), FICE, MIWE, FASCE, Association of Consulting Engineers

P. B. Ahm, MSc, FICE, Association of Consulting Engineers

*R. B. Hill, BSc, FICE, FISTructE, Federation of Civil Engineering Contractors

J. A. Sneden, FRICS, FIQS, Federation of Civil Engineering Contractors

J. B. B. Newton, BSc(Eng), FICE, co-opted

N. C. B. Brierley, BSc(Eng), FICE, co-opted

Late in 1972 a draft of the revised standard method of measurement was circulated for comment to 71 representative bodies. Trial Bills of Quantities were prepared by 20 organizations. Discussions with interested bodies continued throughout 1973 and 1974 and the form of the present document owes much to the suggestions made during this time by bodies outside the committee. The Steering Committee is indebted to the many people who helped in this way.

The object of the work has been to make improvements while retaining the good features of the previous edition of the standard method of measurement. The principal improvements sought are

- (a) to standardize the layout and contents of Bills of Quantities prepared according to the standard method of measurement
- (b) to provide a systematic structure of bill items leading to more uniform itemization and description
- (c) to review the subdivision of work into items so that a more sensitive and balanced description of the value of work in a contract is provided
- (d) to take account of new techniques in civil engineering construction and management, their influence on the work itself and on the administration of contracts.

A Bill of Quantities which in essence is no more than a price list of the Permanent Works no longer adequately reflects the many variables in the cost of civil engineering construction which have resulted from developments in constructional techniques and methods. It has therefore been decided to provide for some additional items of measured work and for other items, entered at the option of the tenderer, directly related to methods of construction.

A system of work classification has been adopted as the basis of the method of measurement so that Bills of Quantities can be compiled and used more easily. The system should enable much of the repetitive clerical work associated with the use of Bills of Quantities to be simplified, and make the use of computers easier.

The Work Classification incorporates a reference number for each type of work component. These reference numbers may be used as a simple code for identification of work. Their use as part of the item numbers in Bills of Quantities is suggested, but is optional. The coding is sufficiently flexible not to inhibit description of the particular work in each contract.

FOREWORD TO THE SECOND EDITION

In 1983 the Council of the Institution of Civil Engineers instructed the CESMM Review Committee to prepare a second edition of the *Civil Engineering Standard Method of Measurement*. The members of the Review Committee were

H. R. Oakley, CBE, FEng, MSc(Eng), FICE, Chairman
D. C. Coope, CBE, FCGI, FICE
N. C. B. Brierley, BSc(Eng), FICE
N. M. L. Barnes, BSc(Eng), PhD, FICE, FCIQB, ACIARB, M8CS

The work of analysing the comments received on the first edition and of drafting the second edition was undertaken by Martin Barnes and Partners who were assisted by McGill and Partners.

Many organizations contributed comments and suggestions for amendment of the document and others participated by reviewing drafts and giving advice. The Review Committee is indebted to the many people who helped in this way, and particularly to the Federation of Civil Engineering Contractors who appointed a committee to review and comment upon the drafts.

The object of the amendments made in the second edition was twofold. Firstly it was to take account of developments in civil engineering technology and in the significance of different costs of civil engineering work which have taken place since the first edition was published. Secondly it was to take the opportunity of altering the wording of the small number of provisions of the first edition which experience had shown were not working either as smoothly as they might or in the way which had been intended. The second edition of the CESMM is consequently not a radical departure from the first edition, but an update and general overhaul.

The two most noticeable changes are the categorization and upgrading of the former notes in the work classification and the introduction of a standard method of measurement for sewer renovation work. The rearrangement of the former notes is intended to make the document easier to use in two ways. Firstly, the notes have been re-named rules in order to emphasize that their provisions govern how work should be described and measured in civil engineering bills of quantities and that they have equal status with rules in any other part of the document. Secondly, they have been divided into four categories to indicate the four separate functions which they perform and have, as far as possible, been laid out alongside the parts of the classification tables to which they relate.

The section for measurement of sewer renovation work has been introduced in order to provide for the considerably increased volume of work of this type now being undertaken. The method of measurement for sewer renovation in this document is based upon that devised originally for the Water Research Centre and included in their standard specification. The Institution of Civil Engineers and the Federation of Civil Engineering Contractors acknowledge the assistance given by the Water Research Centre in allowing this method of measurement to be embodied in the CESMM.

Although the second edition of the *Civil Engineering Standard Method of Measurement* was published in 1985, a number of factors have combined to cause the need for a third edition. The main changes incorporated in the third edition (CESMM3) are amendments to enable its use with the ICE Conditions of Contract, sixth edition (January 1991), and the introduction of a standard method of measurement for water main renovation and for simple building works incidental to civil engineering works (classes Y and Z). Account has also been taken of developments in civil engineering technology and the opportunity taken to make minor amendments and corrections to the text of the second edition. There are no changes in principle or in the general arrangement.

The Review Committee is indebted to a number of organizations and individuals who have contributed comments and suggestions for amendment. The committee is particularly indebted to E. C. Harris: Quantity Surveying whose proposals formed the basis for the new class Z. The work of analysing the comments and suggestions and drafting CESMM3 was undertaken by Coopers & Lybrand Deloitte.

The members of the Review Committee were

H. R. Oakley, CBE, FEng, MSc(Eng), FICE, Chairman
N. M. L. Barnes, FEng, BSc(Eng), PhD, FICE, FCIOB, ACIArb, MBCS, CBIM
Miss R. Beales, Barrister-at-Law
J. Banyard, MICE
H. A. Jones, MICE, Secretary

The committee is indebted to Dr Barnes of Coopers and Lybrand Deloitte for his invaluable advice and assistance throughout.

SECTION 1. DEFINITIONS

1.1. In this document and in Bills of Quantities prepared according to the procedure set forth herein the following words and expressions have the meanings hereby assigned to them, except where the context otherwise requires.

1.2. 'Conditions of Contract' means the *ICE Conditions of Contract*, sixth edition (January 1991), prepared by the Institution of Civil Engineers jointly with the Association of Consulting Engineers and the Federation of Civil Engineering Contractors.

1.3. Words and expressions defined in the Conditions of Contract have the same meanings herein.

1.4. All references to clauses are references to clauses numbered in the Conditions of Contract and references to paragraphs are references to paragraphs numbered herein.

1.5. The word 'work' includes work to be carried out, goods, materials and services to be supplied, and the liabilities, obligations and risks to be undertaken by the Contractor under the Contract.

1.6. The expression 'expressly required' means shown on the Drawings, described in the Specification or ordered by the Engineer pursuant to the Contract.

1.7. 'Bill of Quantities' means a list of items giving brief identifying descriptions and estimated quantities of the work comprised in a Contract.

1.8. 'Daywork' means the method of valuing work on the basis of time spent by the workmen, the materials used and the plant employed.

1.9. 'Work Classification' means the Work Classification set out in section 8.

1.10. 'Original Surface' means the surface of the ground before any work has been carried out.

1.11. 'Final Surface' means the surface indicated on the Drawings to which excavation is to be carried out.

1.12. 'Commencing Surface' means, in relation to an item in a Bill of Quantities, the surface of the ground before any work covered by the item has been carried out. 'Commencing Surface' means, in relation to a group of items in a Bill of Quantities for work in different materials in an excavation or a bored, drilled or driven hole, the surface of the ground before any work covered by any item in the group has been carried out.

1.13. 'Excavated Surface' means, in relation to an item in a Bill of Quantities, the surface to which excavation included in the work covered by the item is to be carried out. 'Excavated Surface' means, in relation to a group of items in a Bill of Quantities for excavation in different materials, the surface to which excavation included in the work covered by any item in the group is to be carried out.

1.14. A hyphen between two dimensions means a range of dimensions which includes all dimensions exceeding that preceding the hyphen but not exceeding that following the hyphen.

1.15. 'BS' means British Standard. References to British Standards are deemed to include equivalent national standards of member states of the European Community and European Community standards.

SECTION 2. GENERAL PRINCIPLES

Title application and extent

2.1. The title of this document is the *Civil Engineering Standard Method of Measurement*, third edition, which is abbreviated to CESMM3. CESMM3 is intended to be used in conjunction with the Conditions of Contract and only in connection with civil engineering works and simple building works incidental to civil engineering works.

2.2. CESMM3 provides for simple building works incidental to civil engineering works to be measured in accordance with class Z. CESMM3 does not deal with the preparation of Bills of Quantities for complex mechanical or electrical engineering work, or complex building work or work which is seldom encountered in civil engineering contracts. Where any such work is to be included in a Contract for civil engineering work, it shall be itemized and described in the Bill of Quantities in sufficient detail to enable tenderers to price it adequately and the method of measurement shall be stated in the Preamble to the Bill of Quantities in accordance with paragraph 5.4.

Object of CESMM3

2.3. The object of CESMM3 is to set forth the procedure according to which the Bill of Quantities shall be prepared and priced and the quantities of work expressed and measured.

Objects of the Bill of Quantities

2.4. The objects of the Bill of Quantities are

- (a) to provide such information of the quantities of work as to enable tenders to be prepared efficiently and accurately
- (b) when a Contract has been entered into, to provide for use of the priced Bill of Quantities in the valuation of work executed.

2.5. In order to attain these objects, work should be itemized in the Bill of Quantities in sufficient detail for it to be possible to distinguish between the different classes of work, and between work of the same nature carried out in different locations or in any other circumstances which may give rise to different considerations of cost. Consistent with these requirements the layout and content of the Bill of Quantities should be as simple and brief as possible.

2.6. All work which is expressly required should be covered in the Bill of Quantities.

2.7. CESMM3 seeks to attain these objects principally by the use of the Work Classification. This defines

- (a) how work is to be divided into separate items in the Bill of Quantities
- (b) the information to be given in item descriptions
- (c) the units in which the quantities against each item are to be expressed
- (d) how the work is to be measured for the purpose of calculating quantities.

SECTION 3. APPLICATION OF THE WORK CLASSIFICATION

Item descriptions	<p>3.1. The Work Classification divides work commonly encountered in civil engineering contracts into 26 main classes. Each class comprises up to three divisions which classify work at successive levels of detail. Each division comprises a list of up to eight descriptive features of work. Each item description in the Bill of Quantities shall identify the component of work covered with respect to one feature from each division of the relevant class, e.g.</p> <p>Class H (precast concrete) contains three divisions of classification. The first classifies different types of precast concrete units, the second classifies different units by their dimensions, and the third classifies them by their mass. Each item description for precast concrete units shall therefore identify the component of work in terms of the type of unit, its dimensions and mass.</p>
Mode of description	<p>3.2. To avoid unnecessary length, item descriptions for Permanent Works shall generally identify the component of the Works and not the tasks to be carried out by the Contractor, e.g.</p> <p>An item should be described as 'Plain round mild steel bar reinforcement to BS 4449 nominal size 20 mm', not as 'Supply, deliver, cut, bend and fix plain round mild steel bar reinforcement to BS 4449 nominal size 20 mm'.</p> <p>3.3. Where the work identified by an item is specifically limited, the limitation shall be stated in the item description, e.g.</p> <p>'Plain round mild steel bar reinforcement to BS 4449 nominal size 20 mm excluding supply and delivery to the Site.'</p> <p>Item descriptions for work which is divided between two classes require such limitations to be stated, e.g.</p> <p>Item descriptions for miscellaneous metalwork inserts which are to be cast into concrete require appropriate additional description if items are given in both class G for casting in the inserts and class N for supplying the inserts.</p>
Separate items	<p>3.4. The work shall be divided into items in the Bill of Quantities so that the component of work which is included in each item does not exhibit more than one feature from each division of any one class of the Work Classification, e.g.</p> <p>One item for precast concrete work shall not include more than one of the types of concrete unit listed in the first division of class H, neither shall it include different units whose dimensions are not within one of the classifications listed in the second division of class H, nor shall it include different units whose mass does not lie within one of the ranges listed in the third division of class H.</p>
Units of measurement	<p>3.5. The unit of measurement for each item shall be that stated for the item in the Work Classification. The unit of measurement stated against a descriptive feature in the Work Classification shall apply to all items to which that descriptive feature applies.</p>
Measurement rules	<p>3.6. Measurement rules in the Work Classification set out the conditions under which work shall be measured and the method by which the quantities shall be computed if other than in accordance with paragraph 5.18.</p>
Definition rules	<p>3.7. Definition rules in the Work Classification define the extent and limits of the class of work represented by a word or expression used in the Work Classification and in a Bill of Quantities prepared in accordance with CESMM3.</p>
Coverage rules	<p>3.8. Coverage rules in the Work Classification provide that the work stated is deemed to be included in the appropriate items to the extent that such work is included in the Contract. A coverage rule does not state all the work covered by an</p>

item and does not preclude any of the work stated being covered by a Method-Related Charge.

Additional description rules

3.9. Description of an item in addition to that required in accordance with paragraph 3.1 shall be given where required by any provision of section 5 or by any applicable additional description rule in the Work Classification. Where additional description is given, a separate item shall be given for each component of work exhibiting a different additional feature, e.g.

Additional description rule A1 of class H requires that the specification of the concrete in each precast concrete unit shall be stated. Accordingly, this rule also means that separate items shall be given for units cast from concrete of different specifications.

3.10. Where a descriptive feature in the Work Classification identifies a range or group of dimensions and an applicable additional description rule requires the particular dimension to be stated, the range or group of dimensions shall not also be stated, e.g.

Additional description rule A2 of class I requires that the nominal bores of pipes shall be stated in item descriptions. The range of nominal bore taken from the second division of the classification of class I shall not also be stated.

Applicability of rules

3.11. Rules printed on a right-hand page above a double line apply to all work in the class. Other rules on a right-hand page apply to particular groups of items as shown by the classification table.

SECTION 4. CODING AND NUMBERING OF ITEMS

Coding

4.1. For convenience of reference each item in the Work Classification has been assigned a code number consisting of a letter and not more than three digits. The letter corresponds to the class in the Work Classification in which the item occurs and the digits give the position of the item in the first, second and third divisions of the class, e.g.

Code H 1 3 6 identifies an item as

class	H	precast concrete
first division	1	beams
second division	3	length 7–10 m
third division	6	mass 5–10 t

4.2. The symbol * is used in the rules to the Work Classification to indicate all numbers in the appropriate division, e.g.

H 1 3 * means the group of code numbers from H 1 3 1 to H 1 3 8 inclusive.

Item numbers

4.3. Code numbers may be used to number the items in the Bill of Quantities, the items within the Bill of Quantities being listed in order of ascending code number.

4.4. Code numbers used as item numbers in the Bill of Quantities shall not form part of the item descriptions or be taken into account in the interpretation of the Contract.

Coding of unclassified items

4.5. Where a feature of an item is not listed in the Work Classification the digit 9 shall be used in the appropriate positions in the code number.

4.6. Where there is an item to which a division of classification does not apply or for which fewer than three divisions of classification are given the digit 0 shall be used in the appropriate positions in the code number.

Numbering of items with additional description

4.7. Additional description given for an item in accordance with paragraph 3.9 is not represented by the code number. Where code numbers are used as item numbers a suffix number shall be used to distinguish items which have the same code number but different additional description, e.g.

Additional description rule A1 of class H requires that additional description be given for precast concrete units stating their position in the Works and the specification of the concrete used. If three items are required within one part of the Bill of Quantities to allow for precast concrete beams having the same code but different additional description, the items should be numbered

H 1 3 6 . 1
H 1 3 6 . 2
H 1 3 6 . 3

SECTION 5. PREPARATION OF THE BILL OF QUANTITIES

- Measurement of completed work** 5.1. Appropriate provisions of this section shall also apply to the measurement of completed work.
- Sections of the Bill of Quantities** 5.2. The Bill of Quantities shall be divided into the following sections.
- (a) List of principal quantities
 - (b) Preamble
 - (c) Daywork Schedule
 - (d) Work items (grouped into parts)
 - (e) Grand Summary.
- List of principal quantities** 5.3. A list of the principal components of the Works with their approximate estimated quantities shall be given solely to assist tenderers in making a rapid assessment of the general scope and character of the proposed Works prior to the examination of the remainder of the Bill of Quantities and the other contractual documents on which their tenders will be based.
- Preamble** 5.4. The Preamble shall state the methods of measurement other than CESMM3, if any, which have been adopted in the preparation of the Bill of Quantities and are to be used for the measurement of any part of the Works. Such methods of measurement shall comprise those adopted and to be used for any work not covered by CESMM3 and any amendments to CESMM3 which have been adopted and are to be used. Amendments comprising abbreviation of CESMM3 are usually necessary for Contractor-designed work and work which is intended to involve selection between alternatives at the discretion of the Contractor. The extent of the work affected by all amendments to CESMM3 shall be stated in the Preamble.
- 5.5. Where excavation, boring or driving is included in the work a definition of rock shall be given in the Preamble and this definition shall be used for the purposes of measurement.
- Daywork Schedule** 5.6. The Daywork Schedule, if any, shall comprise either
- (a) a list of the various classes of labour, materials and plant for which Daywork rates or prices are to be inserted by the tenderer together with a statement of the conditions under which the Contractor shall be paid for work executed on a Daywork basis, or
 - (b) a statement that the Contractor shall be paid for work executed on a Daywork basis at rates and prices calculated by adding the percentage additions stated in the *Schedules of Dayworks carried out incidental to Contract Work* issued by the Federation of Civil Engineering Contractors to the rates and prices contained in the aforementioned *Schedules* and by making further adjustments as follows.
- | | |
|------------------------------------|------------------------------------|
| Schedule 1: Labour | addition/deduction* of — †per cent |
| Schedule 2: Materials | addition/deduction* of — †per cent |
| Schedule 3: Plant | addition/deduction* of — †per cent |
| Schedule 4: Supplementary charges‡ | addition/deduction* of — †per cent |
- *Appropriate deletion to be made by the Contractor when tendering
 †Percentage to be inserted by the Contractor when tendering
 ‡Supplementary charges shall not include the charges referred to in notes and conditions 2(ii), 3 and 6 of schedule 4
- Payments shall be made under the conditions and using the rates and prices contained in the edition of the aforementioned *Schedules* current at the date of execution of the Daywork.

5.7. Provisional Sums for work executed on a Daywork basis may be given comprising separate items for labour, materials, plant and supplementary charges. Where a Daywork Schedule of the form stated in sub-paragraph (b) of paragraph 5.6 is used each Provisional Sum shall be followed by an item for the adjustment referred to in that sub-paragraph. The price inserted against each such item shall be calculated by applying the percentage addition or deduction inserted by the Contractor in the Daywork Schedule to the amount of the associated Provisional Sum.

Work items

Division of the Bill of Quantities into parts

5.8. The items in the Bill of Quantities which are to be priced and to contribute to the Tender Total may be arranged into numbered parts to distinguish between those parts of the work of which the nature, location, access, limitation on sequence or timing or any other special characteristic is thought likely to give rise to different methods of construction or considerations of cost. General items (class A) may be grouped as a separate part of the Bill of Quantities. Items in each part shall be arranged in the general order of the Work Classification.

Headings and sub-headings

5.9. Each part of the Bill of Quantities shall be given a heading and groups of items within each part be given sub-headings. Headings and sub-headings shall be read as part of the item descriptions to which they apply. A line shall be drawn across the item description column below the last item to which each heading or sub-heading applies. Headings and sub-headings shall be repeated at the start of each new page which lists items to which they apply.

Extent of itemization and description

5.10. All work shall be itemized and the items shall be described in accordance with the Work Classification, but further itemization and additional description may be provided if the nature, location, importance or any other special characteristic of the work is thought likely to give rise to special methods of construction or considerations of cost.

Descriptions

5.11. Descriptions shall identify the work covered by the respective items, but the exact nature and extent of the work is to be ascertained from the Drawings, Specification and Conditions of Contract, as the case may be, read in conjunction with the Work Classification.

5.12. Any detail of description required to be given in accordance with the Work Classification may be omitted from an item description provided that a reference is given in its place which identifies precisely where the omitted information may be found on a drawing or in the Specification.

5.13. Where an item description compiled in accordance with the Work Classification would be insufficient to identify clearly the particular work covered by the item additional description shall be given to identify the work by reference to its location or other physical features shown on the Drawings or described in the Specification.

Ranges of dimensions

5.14. Where all the components of work included in an item are of one dimension within a range given in the Work Classification that dimension may be stated in the item description in place of the range of dimensions given.

Prime Cost Items

5.15. The estimated price of work to be carried out by a Nominated Sub-contractor shall be given in the Bill of Quantities as a Prime Cost Item. Each Prime Cost Item shall be followed by

- (a) an item for a sum for labours in connection therewith which, in the absence of any express provision in the Contract to the contrary, shall include *only*
 - (i) in any case in which the Nominated Sub-contractor is to carry out work

on the Site for allowing him to use temporary roads, scaffolding, hoists, messrooms, sanitary accommodation and welfare facilities which are provided by the Contractor for his own use and for providing space for office accommodation and storage of plant and materials, for disposing of rubbish and for providing light and water for the work of the Nominated Sub-contractor, and

(ii) in any case in which the Nominated Sub-contractor is not to carry out work on the Site for unloading, storing and hoisting materials supplied by him and returning packing materials, and

(b) an item expressed as a percentage of the price of the Prime Cost Item in respect of all other charges and profit.

5.16. Where any goods, materials or services supplied by a Nominated Sub-contractor are to be used by the Contractor in connection with any item, reference shall be made in the description of that item, or in the appropriate heading or sub-heading, to the Prime Cost Item under which the goods or materials or services are to be supplied.

5.17. Provision for contingencies shall be made by giving Provisional Sums in the Bill of Quantities and not by increasing the quantities beyond those of the work expected to be required. Provisional Sums for specific contingencies shall be given in the general items of the Bill of Quantities. A Provisional Sum for a general contingency allowance, if required, shall be given in the Grand Summary in accordance with paragraph 5.25.

5.18. The quantities shall be computed net using dimensions from the Drawings, unless directed otherwise by a measurement rule in CESMM3 or by the Contract, and no allowance shall be made for bulking, shrinkage or waste. Quantities may be rounded up or down where appropriate. Fractional quantities are not generally necessary and should not be given to more than one place of decimals.

5.19. The following units of measurement and abbreviations shall be used.

Unit	Abbreviation
Millimetre	mm
Metre	m
Square millimetre	mm ² or mm2
Square metre	m ² or m2
Hectare	ha
Cubic metre	m ³ or m3
Kilogramme	kg
Tonne	t
Sum	sum
Number	nr
Hour	h
Week	wk

5.20. Where an existing body of open water (other than groundwater) such as a river, stream, canal, lake or body of tidal water is either on the Site or bounds the Site, each body of water shall be identified in the Preamble to the Bill of Quantities. A reference shall also be given to a drawing indicating the boundaries and surface level of each body of water or, where the boundaries and surface levels fluctuate, their anticipated ranges of fluctuation.

5.21. The Commencing Surface shall be identified in the description of each item for work involving excavation, boring or driving for which the Commencing Surface is not the Original Surface. The Excavated Surface shall be identified in the

Provisional Sums

Quantities

Units of measurement

Work affected by water

Ground and excavation levels

description of each item for work involving excavation for which the Excavated Surface is not the Final Surface. The depths of excavation stated in accordance with the Work Classification shall be measured from the Commencing Surface to the Excavated Surface.

Form and setting

5.22. The Bill of Quantities should be set out on paper of A4 size. The work items should be set out within columns headed and ruled consecutively as follows.

<i>Column heading</i>	<i>Column width</i>
Number	20 mm
Item description	90 mm
Unit	10 mm
Quantity	20 mm
Rate	20 mm
Amount: £	20 mm
ρ	8 mm

5.23. Provision shall be made for the amounts inserted on each page to be totalled and carried to a summary of each part of the Bill of Quantities and for the total of each Part Summary to be carried to the Grand Summary.

Grand Summary

5.24. The Grand Summary shall contain a tabulation of the parts of the Bill of Quantities with provision for insertion of the total of the amounts brought forward from the Part Summaries.

General Contingency Allowance

5.25. A Provisional Sum for a general contingency (the General Contingency Allowance), if required, shall be given in the Grand Summary following the total of the amounts brought forward from the Part Summaries.

Adjustment Item

5.26. An item described as the Adjustment Item shall be given in the Grand Summary following the total of the amounts brought forward from the Part Summaries and the General Contingency Allowance, if any (see paragraphs 6.3, 6.4 and 6.5).

Total of the Priced Bill of Quantities

5.27. Provision shall be made for insertion of the total of the amounts brought forward from the Part Summaries; the amount of the General Contingency Allowance, if any, and the amount of the Adjustment Item.

SECTION 6. COMPLETION, PRICING AND USE OF THE BILL OF QUANTITIES

Insertion of rates and prices

6.1. Rates and prices shall be inserted in the rate column of the Bill of Quantities in pounds sterling with pence inserted as decimal fractions of one pound.

Parts to be totalled

6.2. Each part of the Bill of Quantities shall be totalled and the totals carried to the Grand Summary.

Adjustment Item

6.3. A tenderer may insert a lump sum addition or deduction against the Adjustment Item given in the Grand Summary in adjustment of the total of the priced Bill of Quantities.

6.4. For the purposes of clause 60 interim additions or deductions on account of the amount, if any, of the Adjustment Item shall be made by instalments in interim certificates in the proportion that the amount referred to in clause 60(2)(a) bears to the total of the priced Bill of Quantities before the addition or deduction of the amount of the Adjustment Item and a statement to this effect shall appear in the Preamble to the Bill of Quantities. Such interim additions or deductions shall be made before deduction of the retention moneys, and shall not exceed in the aggregate the amount of the Adjustment Item. If by the date of issue pursuant to clause 48 of the Certificate of Substantial Completion for the whole of the Works any balance of the amount of the Adjustment Item is outstanding it shall be added to or deducted from the moneys then due.

6.5. In determining the Effective Value for the purposes of the Contract Price Fluctuations clause, if applicable, account shall be taken of any addition to or deduction from the amounts due to the Contractor under clause 60 in respect of the Adjustment Item.

SECTION 7. METHOD-RELATED CHARGES

Definitions	<p>7.1. For the purposes of this section the following words and expressions shall have the meanings hereby assigned to them.</p> <p>(a) 'Method-Related Charge' means the sum for an item inserted in the Bill of Quantities by a tenderer in accordance with paragraph 7.2.</p> <p>(b) 'Time-Related Charge' means a Method-Related Charge for work the cost of which is to be considered as proportional to the length of time taken to execute the work.</p> <p>(c) 'Fixed Charge' means a Method-Related Charge which is not a Time-Related Charge.</p>
Insertion by a tenderer	<p>7.2. A tenderer may insert in the Bill of Quantities such items for Method-Related Charges as he may decide to cover items of work relating to his intended method of executing the Works, the costs of which are not to be considered as proportional to the quantities of the other items and for which he has not allowed in the rates and prices for the other items.</p>
Itemization	<p>7.3. Where possible the itemization of Method-Related Charges should follow the order of classification and the other requirements set out in class A of the Work Classification, distinguishing between Time-Related Charges and Fixed Charges. Method-Related Charges may be inserted to cover items of work other than those set out in class A.</p>
Description	<p>7.4. Each item for a Method-Related Charge inserted in the Bill of Quantities shall be fully described so as to define precisely the extent of the work covered and to identify the resources to be used and the particular items of Permanent Works or Temporary Works, if any, to which the item relates.</p>
Contractor not bound to adopt method	<p>7.5. The insertion by the Contractor of an item for a Method-Related Charge in the Bill of Quantities when tendering shall not bind him to adopt the method stated in the item description in executing the Works.</p>
Charges not to be measured	<p>7.6. Method-Related Charges shall not be subject to admeasurement but shall be deemed to be prices for the purposes of clauses 52(1), 52(2) and 56(2).</p>
Payment	<p>7.7. Method-Related Charges shall be certified and paid pursuant to clauses 60(1)(d) and 60(2)(a) and a statement to this effect shall appear in the Preamble to the Bill of Quantities.</p>
Payment when method not adopted	<p>7.8. In the event of the satisfactory execution of any part of the Works which has been the subject of an item for a Method-Related Charge using, whether in whole or in part, a method other than that described in the item the Contractor shall nevertheless be entitled to payment of the Method-Related Charge or the balance thereof, as the case may be, by such instalments at such times and upon such events as may from time to time be agreed between the Engineer and the Contractor. In default of such agreement the Method-Related Charge, or the balance then unpaid, shall be treated as if it were an addition to the Adjustment Item referred to in paragraphs 6.3, 6.4 and 6.5 and allowed to the Contractor by way of instalments in interim certificates accordingly. The amount of a Method-Related Charge shall be neither increased nor decreased by reason only of any change in method made by the Contractor, unless such change has been ordered by the Engineer, in which case the provisions of clause 52 shall apply.</p>

SECTION 8. WORK CLASSIFICATION

- Class A: General items, 16
- Class B: Ground investigation, 20
- Class C: Geotechnical and other specialist processes, 28
- Class D: Demolition and site clearance, 32
- Class E: Earthworks, 34
- Class F: In situ concrete, 40
- Class G: Concrete ancillaries, 42
- Class H: Precast concrete, 46
- Class I: Pipework—pipes, 48
- Class J: Pipework—fittings and valves, 50
- Class K: Pipework—manholes and pipework ancillaries, 52
- Class L: Pipework—supports and protection, ancillaries to laying and excavation, 56
- Class M: Structural metalwork, 60
- Class N: Miscellaneous metalwork, 62
- Class O: Timber, 64
- Class P: Piles, 66
- Class Q: Piling ancillaries, 70
- Class R: Roads and pavings, 74
- Class S: Rail track, 78
- Class T: Tunnels, 82
- Class U: Brickwork, blockwork and masonry, 88
- Class V: Painting, 90
- Class W: Waterproofing, 92
- Class X: Miscellaneous work, 94
- Class Y: Sewer and water main renovation and ancillary works, 96
- Class Z: Simple building works incidental to civil engineering works, 102

CLASS A: GENERAL ITEMS

Includes: General obligations, site services and facilities, Temporary Works, testing of materials and work, Provisional Sums and Prime Cost Items
Items to cover elements of the cost of the work which are not to be considered as proportional to the quantities of the Permanent Works

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Contractual requirements	1 Performance bond 2 Insurance of the Works 3 Third party insurance	
2 Specified requirements	1 Accommodation for the Engineer's staff	1 Offices 2 Laboratories 3 Cabins
	2 Services for the Engineer's staff	1 Transport vehicles 2 Telephones
	3 Equipment for use by the Engineer's staff	1 Office equipment 2 Laboratory equipment 3 Surveying equipment
	4 Attendance upon the Engineer's staff	1 Drivers 2 Chairmen 3 Laboratory assistants
	5 Testing of materials 6 Testing of the Works	
	7 Temporary Works	1 Traffic diversions 2 Traffic regulation 3 Access roads 4 Bridges 5 Cofferdams 6 Pumping 7 De-watering 8 Compressed air for tunnelling
	3 Method-Related Charges	1 Accommodation and buildings
2 Services		1 Electricity 2 Water 3 Security 4 Hoardings 5 Site transport 6 Personnel transport 7 Welfare
3 Plant		1 Cranes 2 Transport 3 Earthmoving 4 Compaction 5 Concrete mixing 6 Concrete transport 7 Pile driving 8 Pile boring
4 Plant		1 Pipelaying 2 Paving 3 Tunnelling 4 Crushing and screening 5 Boring and drilling

(continued)

CLASS A

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The unit of measurement for general items shall be the sum, except where another unit of measurement is used in accordance with rule M2.</p>			
		<p>C1 Items for insurance classed as <i>contractual requirements</i> shall be deemed to include only provision of insurance in accordance with clauses 21 and 23 unless otherwise stated.</p>	
<p>M2 A quantity shall be given against all items for <i>specified requirements</i> of which the value is to be ascertained and determined by admeasurement in accordance with clause 56(1). A unit of measurement shall be stated for each such item.</p> <p>M3 Items shall be given in this class for all <i>testing</i> for which items are not given separately as set out in other classes.</p>	<p>D1 All work other than the Permanent Works which is expressly stated in the Contract to be carried out by the Contractor and of which the nature and extent is expressly stated in the Contract shall be classed as <i>specified requirements</i>.</p>		<p>A1 Item descriptions for work classed as <i>specified requirements</i> which is to be carried out after the issue of the Certificate of Substantial Completion shall so state.</p> <p>A2 Item descriptions for work classed as <i>specified requirements</i> shall distinguish between the establishment and removal of services or facilities and their continuing operation or maintenance.</p> <p>A3 Item descriptions for <i>testing of materials and testing of the Works</i> shall include particulars of samples and of methods of testing.</p>
<p>M4 Items for <i>Method-Related Charges</i>, if any, shall be inserted by the tenderer in accordance with section 7.</p>			<p>A4 Item descriptions for <i>Method-Related Charges</i> shall distinguish between Fixed and Time-Related Charges.</p>

NOTE

Method-Related Charges may be inserted by the tenderer in accordance with paragraph 7.2 for insurances additional to those classed as contractual requirements.

CLASS A

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
3 Method-Related Charges (continued)	5 Temporary Works	1 Traffic diversions 2 Traffic regulation 3 Access roads 4 Bridges 5 Cofferdams 6 Pumping 7 De-watering 8 Compressed air for tunnelling
	6 Temporary Works	1 Access scaffolding 2 Support scaffolding and propping 3 Piling 4 Formwork 5 Shafts and pits 6 Hardstandings
	7 Supervision and labour	1 Supervision 2 Administration 3 Labour teams
4 Provisional Sums	1 Daywork	1 Labour 2 Percentage adjustment to Provisional Sum for Daywork labour 3 Materials 4 Percentage adjustment to Provisional Sum for Daywork materials 5 Plant 6 Percentage adjustment to Provisional Sum for Daywork plant 7 Supplementary charges 8 Percentage adjustment to Provisional Sum for Daywork supplementary charges
	2 Other Provisional Sums	
5 Nominated Sub-contracts which include work on the Site	1 Prime Cost Item	
6 Nominated Sub-contracts which do not include work on the Site	2 Labours	
	3 Special labours	
	4 Other charges and profit	

CLASS A

(see rule at head of class on page 17)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M4 Items for <i>Method-Related Charges</i>, if any, shall be inserted by the tenderer in accordance with section 7.</p>			<p>A4 Item descriptions for <i>Method-Related Charges</i> shall distinguish between Fixed and Time-Related Charges.</p>
<p>M5 items for <i>percentage adjustment to Provisional Sums for Daywork</i> shall be given only where a Daywork Schedule in accordance with alternative form (b) of paragraph 5.5 is given in the Bill of Quantities. Adjustments shall be inserted against such items to correspond with the adjustments, if any, inserted by the tenderer in the Daywork Schedule.</p>			
<p>M6 Each <i>Prime Cost Item</i> shall be followed by an item for labours and an item for other charges and profit in accordance with paragraph 5.15. Where labours other than or in addition to those stated in sub-paragraph (a) of paragraph 5.15 are to be provided the item for labours shall be designated as for special labours.</p>			<p>A5 Item descriptions for <i>Prime Cost Items</i> shall identify the work included.</p> <p>A6 The labours shall be stated in item descriptions for <i>special labours</i>.</p>

CLASS B: GROUND INVESTIGATION

Includes: Trial pits and trenches, boreholes, samples, site and laboratory tests, instrumental observations and professional services in connection with ground investigation

Excludes: Excavation not carried out for the purpose of ground investigation (included in class E)
Boring for piling (included in classes P and Q)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION	
1 Trial pits and trenches	1 Number in material other than rock	nr	1 Maximum depth: not exceeding 1 m 2 1-2 m 3 2-3 m 4 3-5 m 5 5-10 m 6 10-15 m 7 15-20 m 8 stated exceeding 20 m
	2 Number in material which includes rock	nr	
	3 Depth in material other than rock	m	
	4 Depth in rock	m	
	5 Depth supported	m	
	6 Depth backfilled, material stated	m	
	7 Removal of obstructions	h	
	8 Pumping at a stated minimum extraction rate	h	
2 Light cable percussion boreholes	1 Number	nr	1 In holes of maximum depth: not exceeding 5 m 2 5-10 m 3 10-20 m 4 20-30 m 5 30-40 m 6 stated exceeding 40 m
	3 Depth	m	
	6 Depth backfilled, material stated	m	
	7 Chiselling to prove rock or to penetrate obstructions	h	
3 Rotary drilled boreholes	1 Number	nr	1 In holes of maximum depth: not exceeding 5 m 2 5-10 m 3 10-20 m 4 20-30 m 5 30-40 m 6 stated exceeding 40 m
	3 Depth without core recovery	m	
	4 Depth with core recovery	m	
	5 Depth cased	m	
	6 Depth backfilled, material stated	m	
	7 Core boxes, length of core stated	nr	

CLASS B

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
		<p>C1 Items for ground investigation shall be deemed to include preparation and submission of records and results.</p> <p>C2 Items for ground investigation shall be deemed to include disposal of excavated material and removal of dead services.</p>	
			<p>A1 Item descriptions for the number and depth of <i>trial pits and trenches</i> shall state the minimum plan area at the bottom of the pit or trench or, where the work is undertaken to <i>locate services</i>, the maximum length of the trench.</p> <p>A2 Item descriptions for the number and depth of <i>trial pits and trenches</i> (B 11-4) shall identify separately those which are expressly required to be excavated by hand.</p>
			<p>A3 Item descriptions for <i>pumping shafts</i> shall state any special dewatering methods which are expressly required.</p>
		<p>C3 Items for the <i>depth of light cable percussion boreholes</i> shall be deemed to include casings.</p>	<p>A4 Item descriptions for the number and depth of <i>light cable percussion boreholes</i> shall state the nominal diameter of the bases of the boreholes.</p>
<p>M1 Chiselling to prove rock or to penetrate obstructions shall be measured only where it is expressly required.</p>			
	<p>D1 <i>Rotary drilled boreholes</i> shall be classified as such whether the boring is carried out by a rig or by an attachment.</p> <p>D2 <i>Core boxes</i> shall be deemed to become the property of the Employer unless otherwise stated.</p> <p>D3 The maximum depth used for classification of <i>rotary drilled boreholes</i> which are continuations of light cable percussion boreholes shall be measured from the Commencing Surface of the light cable percussion borehole.</p>		<p>A5 Item descriptions for <i>rotary drilled boreholes</i> shall state the nominal minimum core diameter.</p> <p>A6 Item descriptions for the number of <i>rotary drilled boreholes</i> shall state those which are continuations of light cable percussion boreholes.</p> <p>A7 Item descriptions for <i>rotary drilled boreholes</i> which are inclined shall state the angle of inclination.</p>

CLASS B

FIRST DIVISION	SECOND DIVISION		THIRD DIVISION				
4 Samples	nr	1 From the surface or from trial pits and trenches	1 Undisturbed soft material 2 Disturbed soft material 3 Rock 4 Groundwater				
		2 From boreholes	1 Open tube 2 Disturbed 3 Groundwater 4 Stationary piston 5 Swedish foil 6 Delft 7 Bishop sand				
5 Site tests and observations	1		1 Permeability	h			
			2 Groundwater level	nr			
			3 Standard penetration	nr			
			4 Penetration vane	nr			
			5 Vane in borehole	nr			
			6 Pressure meter	nr			
			2	1 Plate bearing	nr		
				2 Self-boring pressure meter	nr		
				3 California bearing ratio	nr		
				4 Static cone sounding	nr		
				5 In situ density	nr		
				6 Mackintosh probe	nr		
				7 Hand auger borehole	nr		
6 Instrumental observations	1	1 Pressure head	1 Standpipes	m			
			2 Piezometers	m			
			3 Install covers	nr			
			4 Readings	nr			
	2	2 Inclinometers	1 Installations	m			
			4 Readings	nr			
			3	3 Settlement gauges	1 Installations	nr	
					4	4 Resistivity	4 Readings
5	5 Seismic						
		6					6 Magnetometer
7	7 Self-potential						
		8	8 Gravimetric				

CLASS B

(see rules at head of class on page 21)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
			A8 Item descriptions for <i>samples</i> shall state their size, type and class in accordance with BS 5930.
			A9 Item descriptions for <i>permeability</i> tests shall state the type and give particulars of the tests.
			A10 Item descriptions for <i>groundwater level</i> observations shall state when the measurements are to be taken.
			A11 Item descriptions for <i>standard penetration</i> tests shall state whether they are in light cable percussion boreholes or rotary drilled boreholes.
			A12 Item descriptions for <i>plate bearing</i> tests shall state whether they are in pits and trenches or boreholes or at the surface.
			A13 Item descriptions for <i>static cone sounding</i> tests shall state the maximum depth of the cone and, where electric cones are used, the maximum capacity of the machine.
			A14 Item descriptions for <i>hand auger borehole</i> tests and observations shall state the minimum diameter and the maximum depth of the boreholes.
			A15 Item descriptions for <i>instrumental observations</i> shall state details of the type of observations and the type of protective fences.
		C4 Items for <i>inclinometers</i> and <i>settlement gauges</i> shall be deemed to include provision of special boreholes.	A16 Item descriptions for <i>inclinometers</i> and <i>settlement gauges</i> shall state whether the instruments are in special boreholes.

CLASS B

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
7 Laboratory tests	1 Classification	1 Moisture content 2 Atterberg limits 3 Specific gravity 4 Particle size analysis by sieve 5 Particle size analysis by pipette or hydrometer 6 Frost susceptibility
	2 Chemical content	1 Organic matter 2 Sulphate 3 pH value 4 Contaminants
	3 Compaction	1 Standard 2 Heavy 3 Vibratory
	4 Consolidation	1 Oedometer cell 2 Triaxial cell 3 Rowe cell
	5 Permeability	1 Constant head 2 Falling head
	6 Soil strength	1 Quick undrained triaxial 2 Consolidated undrained triaxial, with pore water pressure measurement 3 Consolidated drained triaxial, with volume change measurement 4 Shearbox: peak only 5 peak and residual 6 residual only 7 ring shear 8 California bearing ratio
	7 Rock strength	1 Unconfined compressive strength of core samples 2 Consolidated drained triaxial, with volume change measurement 3 Brazilian 4 Ring shear 5 Point load

CLASS B

(See rules at head of class on page 21)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
			<p>A17 Item descriptions for tests for contaminants shall state the standards required and the contaminants to be analysed.</p>
			<p>A18 Item descriptions for triaxial cell and Rowe cell tests shall state the number of increments and the effective pressures.</p>
			<p>A19 Item descriptions for quick undrained triaxial tests shall state the diameter and whether a single, multistage or set of three specimens is required.</p> <p>A20 Item descriptions for consolidated triaxial tests shall state the diameter and the effective pressures. Multistage tests shall be identified in item descriptions.</p> <p>A21 Item descriptions for shearbox tests shall state the normal pressures and the size of the shearbox.</p> <p>A22 Item descriptions for California bearing ratio tests shall state the compactive effort, surcharge and whether soaking is required.</p>
			<p>A23 Item descriptions for unconfined compressive strength tests shall state the diameter and the height of the samples.</p> <p>A24 Item descriptions for consolidated drained triaxial tests shall state the diameter and the height of the samples and the effective pressure.</p> <p>A25 Item descriptions for Brazilian tests shall state the diameter and the length of the samples.</p> <p>A26 Item descriptions for ring shear tests shall state the normal pressure and the diameter of the samples.</p> <p>A27 Item descriptions for point load tests shall state the type of test required and the minimum dimensions of the samples.</p>

CLASS B

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
8 Professional services	1 Technician 2 Technician engineer	
	3 Engineer or geologist	1 Graduate 2 Chartered 3 Principal or consultant
	4 Visits to the Site	
	5 Overnight stays in connection with visits to the Site	

CLASS B

(see rules at head of class on page 21)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M2 Professional services shall be measured only where they are expressly required for analysis of records and results.</p> <p>M3 The hours measured shall be working hours and shall exclude hours occupied in travel, meals, etc.</p>		<p>C5 Items for professional services shall be deemed to include preparation and submission of reports and keeping records of time spent.</p> <p>C6 Items for visits to the Site and overnight stays in connection with visits to the Site shall be deemed to include travelling, meals, accommodation and other incidental expenses.</p>	

CLASS C: GEOTECHNICAL AND OTHER SPECIALIST PROCESSES

Includes: Geotechnical processes for altering the properties of soils and rocks
Other specialist processes as listed

Excludes: Compaction (included in class E)
Grouting carried out from within tunnels, shafts and other subterranean cavities (included in class T)
Grouting carried out from within sewers (included in class Y)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Drilling for grout holes through material other than rock or artificial hard material	1 Vertically downwards	1 In holes of depth:
2 Drilling for grout holes through rock or artificial hard material	2 Downwards at an angle 0°-45° to the vertical	2 not exceeding 5 m
3 Driving injection pipes for grout holes	3 Horizontally or downwards at an angle less than 45° to the horizontal	3 5-10 m
	4 Upwards at an angle 0°-45° to the horizontal	4 10-20 m
	5 Upwards at an angle less than 45° to the vertical	5 20-30 m
		6 30-40 m
		6 stated exceeding 40 m
4 Grout holes	nr	
	1 Number of holes	
	2 Number of stages	
	3 Single water pressure tests	
	4 Multiple water pressure tests	
5 Grout materials and injection	1 Materials	1 Cement
		2 Pulverized fuel ash
		3 Sand
		4 Pea gravel
		5 Bentonite
		6 Chemicals
	2 Injection	1 Number of injections
		2 Neat cement grout
		3 Cement and stated filler grout
		4 Chemical grout
		5 Other stated grout
		6 Single packer settings
		7 Double packer settings
6 Diaphragm walls	1 Excavation in material other than rock or artificial hard material	1 Maximum depth: not exceeding 5 m
	2 Excavation in rock	2 5-10 m
	3 Excavation in artificial hard material	3 10-15 m
		4 15-20 m
		5 20-25 m
		6 25-30 m
		7 stated exceeding 30 m
	4 Concrete	
		1 Nominal size: 8 mm
	5 Plain round steel bar reinforcement to BS 4449	2 8 mm
	6 Deformed high yield steel bar reinforcement to BS 4449	3 10 mm
		4 12 mm
		5 16 mm
		6 20 mm
		7 25 mm
		8 32 mm or greater
	7 Waterproofed joints	
	8 Guide walls	

CLASS C

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The Commencing Surface adopted in the preparation of the Bill of Quantities shall be adopted for the measurement of the completed work.</p> <p>M2 The depths of <i>grout holes</i>, holes for <i>ground anchorages</i> and <i>drains</i> shall be measured along the holes irrespective of inclination.</p>	<p>D1 Drilling and excavation for work in this class shall be deemed to be in <i>material other than rock or artificial hard material</i> unless otherwise stated in item descriptions.</p>	<p>C1 Items for work in this class shall be deemed to include disposal of excavated material and removal of dead services.</p>	
<p>M3 Drilling through previously grouted holes in the course of stage grouting shall not be measured. Where holes are expressly required to be extended, the number of holes shall be measured and drilling through previously grouted holes shall be measured as <i>drilling through rock or artificial hard material</i>.</p> <p>M4 The number of stages measured shall be the total number of grouting stages expressly required.</p> <p>M5 The mass of <i>grout materials</i> measured shall not include the mass of mixing water.</p>			<p>A1 The diameters of holes shall be stated in item descriptions for <i>drilling and driving for grout holes</i> and <i>grout holes</i>.</p> <p>A2 The type of materials shall be stated in item descriptions for <i>grout materials</i>.</p>
<p>M6 The number of <i>injections</i> measured shall be the total number of injections expressly required.</p> <p>M7 The mass of <i>grout injection</i> measured shall not include the mass of mixing water.</p>			<p>A3 Item descriptions for the number of injections shall identify those which are in stages distinguishing between those which are in ascending and descending stages.</p>
<p>M8 Formwork for voids, recesses and fillets in <i>diaphragm walls</i> shall be classed as concrete ancillaries (class G).</p> <p>M9 The depths of <i>concrete</i> in diaphragm walls shall be measured from the cut-off levels expressly required. The volume of concrete shall be calculated as set out in rules M1 and M2 in class F.</p> <p>M10 The mass measured for <i>reinforcement</i> in diaphragm walls shall include that of stiffening, fixing and supporting steel casting.</p> <p>M11 The mass of steel <i>reinforcement</i> shall be taken as 785 kg/m per 100 mm² of cross-section (7.85 t/m³). The mass of other reinforcing materials shall be taken as stated in the Contract.</p> <p>M12 <i>Guide walls</i> shall be measured each side of the diaphragm wall.</p>	<p>D2 <i>Diaphragm walls</i> are walls constructed using bentonite slurry or other support fluids.</p> <p>D3 The nominal size stated in item descriptions for <i>bar reinforcement</i> in diaphragm walls shall be the cross-sectional size defined in BS 4449.</p>	<p>C2 Items for <i>excavation</i> for diaphragm walls shall be deemed to include preparation and upholding sides of excavation.</p> <p>C3 Items for <i>concrete</i> in diaphragm walls shall be deemed to include trimming the faces of diaphragm walls and preparing their tops to receive other work.</p> <p>C4 Items for <i>reinforcement</i> in diaphragm walls shall be deemed to include supporting reinforcement and preparing protruding reinforcement to receive other work.</p>	<p>A4 The thicknesses of <i>diaphragm walls</i> shall be stated in item descriptions for <i>excavation and concrete</i> for diaphragm walls.</p> <p>A5 The nature of the material shall be stated in item descriptions for <i>excavation in artificial hard material</i>.</p> <p>A6 The mix specifications or strengths shall be stated in item descriptions for <i>concrete</i> in diaphragm walls.</p>

CLASS C

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
7 Ground anchorages	1 Number in material other than rock or artificial hard material to a stated maximum depth 2 Total length of tendons in material other than rock or artificial hard material 3 Number in material which includes rock or artificial hard material to a stated maximum depth 4 Total length of tendons in material which includes rock or artificial hard material	1 Temporary 2 Temporary with single corrosion protection 3 Temporary with double corrosion protection 4 Permanent 5 Permanent with single corrosion protection 6 Permanent with double corrosion protection
8 Sand, band and wick drains	1 Number of drains 2 Number of predrilled holes 3 Depth of overlying material 4 Depth of drains of maximum depth; not exceeding 10 m 5 10-15 m 6 15-20 m 7 20-25 m 8 stated exceeding 25 m	1 Cross-sectional dimension: not exceeding 100 mm 2 100-200 mm 3 200-300 mm 4 300-400 mm 5 400-500 mm 6 stated exceeding 500 mm

CLASS C

(see rules at head of class on page 28)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M13 The lengths of tendons for ground anchorages shall be measured between the outer ends of anchorages.</p>			<p>A7 The composition, location and working load and details of water and grout testing, pregrouting and grouting shall be stated in item descriptions for ground anchorages.</p>
<p>M14 The number of predrilled holes measured for sand, band and wick drains shall be the number expressly required to be predrilled through overlying material.</p>			<p>A8 Sand drains, band drains and wick drains shall be separately identified in item descriptions and the materials of which they are composed stated.</p>

CLASS D: DEMOLITION AND SITE CLEARANCE

Includes: Demolition and removal of natural and artificial articles, objects and obstructions which are above the Original Surface

Excludes: Removal of articles, objects, obstructions and materials (other than tree roots) at or below the Original Surface (included in classes C, E, I, J, K, L, R, T, X and Y)

FIRST DIVISION		SECOND DIVISION		THIRD DIVISION
1	General clearance	na		
2	Trees	nr	1 Girth: 500 mm-1 m 2 1-2 m 3 2-3 m 4 3-5 m 5 exceeding 5 m	
3	Stumps	nr	1 Diameter: 150-500 mm 2 500 mm-1 m 3 exceeding 1 m	
4	Buildings	sum	1 Brickwork 2 Concrete 3 Masonry 4 Metal 5 Timber 6 No predominant material	1 Volume: not exceeding 50 m ³ 2 50-100 m ³ 3 100-250 m ³ 4 250-500 m ³ 5 500-1000 m ³ 6 1000-2500 m ³ 7 2500-5000 m ³ 8 stated exceeding 5000 m ³
5	Other structures	sum		
6	Pipelines	m	1 Nominal bore: 100-300 mm 2 300-500 mm 3 exceeding 500 mm	

CLASS D

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
		C1 Items for demolition and site clearance shall be deemed to include disposal of the materials arising	A1 Item descriptions for work from which the materials arising remain the property of the Employer shall so state.
	D1 <i>General clearance</i> shall include the demolition and removal of all articles, objects and obstructions which are expressly required to be cleared, except those for which separate items are given as set out in this class.	C2 Items for <i>general clearance</i> which include the removal of hedges shall be deemed to include the removal of hedge stumps of any diameter where these are also required to be removed.	A2 Item descriptions for <i>general clearance</i> shall identify the area included unless it is the total area of the Site. A3 Where holes left by stump removal are to be backfilled, item descriptions for <i>general clearance</i> , trees and stumps shall state the nature of the backfilling material.
	D2 Girths of trees shall be measured 1 m above ground level.	C3 Items for clearance of trees shall be deemed to include removal of the stumps where they are also required to be removed.	
	D3 The volume used in the classification of buildings and other structures shall be their approximate volume occupied, excluding any volume below the Original Surface.		A4 Buildings and other structures shall be identified in item descriptions.
M1 Pipelines within buildings and other structures shall be measured only where their nominal bore exceeds 300 mm.		C4 Items for demolition of pipelines shall be deemed to include demolition and removal of supports.	

CLASS E: EARTHWORKS

Includes: Excavation, dredging, filling, compaction, disposal and landscaping

Excludes: Excavation for:
 ground investigation (included in class B)
 diaphragm walls and ground anchorages (included in class C)
 pipes and sewers, manholes, trenches and ditches, pipe headings, thrust boring and pipe jacking, and pipe jointing (included in classes I, J, K, L and Y)
 piles (included in classes P and Q)
 foundations for traffic signs (included in class R)
 tunnels, shafts, headings and other subterranean cavities (included in class T)
 foundations for fences and gates (included in class X)
 Reinstatement following pipe laying (included in class K)

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
1	Excavation by dredging	1	1 Maximum depth: not exceeding 0.25 m 2 0.25-0.5 m 3 0.5-1 m 4 1-2 m 5 2-5 m 6 5-10 m 7 10-15 m 8 stated exceeding 15 m
2	Excavation for cuttings	2	
		3	
3	Excavation for foundations	4	
4	General excavation	5	
		6	
		7	
		8	
		1	
		2	
		3	
		4	
		5	
		6	
		7	
		8	

CLASS E

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 In accordance with paragraph 5.18 the quantities of earthworks shall be computed net using dimensions from the Drawings with no allowance for bulking, shrinkage or waste. Where boundaries between different materials are not shown on the Drawings, measurement shall be made on the Site.</p>			
<p>M2 The Commencing Surface adopted in the preparation of the Bill of Quantities shall be adopted for the measurement of the completed work.</p> <p>M3 Excavation classed as by dredging in the Bill of Quantities shall be measured as by dredging irrespective of the method of excavation adopted by the Contractor.</p> <p>M4 Measurement of excavation by dredging shall be made from soundings unless otherwise stated.</p> <p>M5 An item shall be given for each separate stage of excavation where separate stages in the conduct of the Works are expressly required.</p> <p>M6 The volume measured for the excavation of a structure or foundation shall be the volume which is to be either occupied by or vertically above any part of the structure or foundation.</p> <p>M7 The volume measured for excavation below a body of open water shall be the volume below water when the water surface is at a higher level (or the higher level of excavation if applicable) shown on the drawing to which reference is given in the Preamble in accordance with paragraph 5.20.</p> <p>M8 An isolated volume of artificial hard material or rock occurring within other material to be excavated shall not be measured separately unless its volume exceeds 1 m³ except that a minimum volume shall be 1 m³ where the net width of excavation is less than 2 m.</p> <p>M9 The volume measured for excavation within borrow pits shall be the net volume measured after filling.</p>	<p>D1 Excavated material shall be deemed to be material other than topsoil, rock or artificial hard material unless otherwise stated in item descriptions.</p> <p>D2 Excavation in or under an embankment, executed prior to placing of fill, shall be classed as excavation for cuttings.</p> <p>D3 Excavation from within borrow pits shall be classed as general excavation.</p>	<p>C1 Items for excavation shall be deemed to include upholding sides of excavation, additional excavation to provide working space and removal of deep services.</p> <p>C2 Items for excavation within borrow pits shall be deemed to include removal and replacement of overburden and unsuitable material.</p>	<p>A1 The location and limits of excavation by dredging shall be stated in item descriptions where its extent would otherwise be uncertain.</p> <p>A2 Item descriptions for excavation below a body of open water identified in the Preamble in accordance with paragraph 5.20 shall identify the body of water.</p> <p>A3 The location and limits of excavation for foundations shall be stated in item descriptions where the limits would otherwise be uncertain. Excavation around pile shafts and for underpinning shall each be so described and classed as excavation for foundations.</p> <p>A4 The Commencing Surface shall be identified in the description of each item for work involving excavation for which the Commencing Surface is not the Original Surface. The Excavated Surface shall be identified in the description of each item for work involving excavation for which the Excavated Surface is not the Final Surface.</p> <p>A5 Item descriptions for excavation within borrow pits shall so state.</p> <p>A6 Item descriptions shall identify separately excavation which is expressly required to be carried out by hand.</p>

CLASS E

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
5 Excavation ancillaries	<ol style="list-style-type: none"> 1 Trimming of excavated surfaces m^2 2 Preparation of excavated surfaces m^2 3 Disposal of excavated material m^2 4 Double handling of excavated material m^3 5 Dredging to remove silt m^3 6 Excavation of material below the Final Surface and replacement with stated material m^3 7 Timber supports left in m^2 8 Metal supports left in m^2 	<ol style="list-style-type: none"> 1 Topsoil 2 Material other than topsoil, rock or artificial hard material 3 Rock 4 Stated artificial hard material
6 Filling	<ol style="list-style-type: none"> 1 To structures m^3 2 Embankments m^3 3 General m^3 4 To stated depth or thickness m^2 	<ol style="list-style-type: none"> 1 Excavated topsoil 2 Imported topsoil 3 Non-selected excavated material other than topsoil or rock 4 Selected excavated material other than topsoil or rock 5 Imported natural material other than topsoil or rock 6 Excavated rock 7 Imported rock 8 Imported artificial material

CLASS E

(see rule at head of class on page 35)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M10 <i>Trimming of excavated surfaces</i> shall be measured to surfaces which are to receive no Permanent Works whether trimming is expressly required or not.</p> <p>M11 <i>Preparation of excavated surfaces</i> shall be measured to surfaces which are to receive Permanent Works whether preparation is expressly required or not except surfaces which are to receive filling or landscaping and surfaces for which formwork is measured.</p> <p>M12 The volume of <i>disposal of excavated material</i> measured shall be the difference between the total net volume of excavation and the net volume of excavated material used for filling.</p> <p>M13 <i>Double handling of excavated material</i> shall be measured only to the extent that it is expressly required. The volume measured for double handling shall be that of the void formed in the temporary stockpile from which the material is removed.</p> <p>M14 <i>Dredging to remove silt</i> shall be measured only to the extent that it is expressly required that silt which accumulates after the Final Surface has been reached shall be removed.</p> <p>M15 The area measured for <i>timber or metal supports left in</i> shall be the area of supported surfaces for which the supports are expressly required to be left in.</p>	<p>D4 <i>Disposal of excavated material</i> shall be deemed to be disposal off the Site unless otherwise stated in item descriptions.</p> <p>D5 <i>Trimming, preparation, disposal and double handling</i> shall be deemed to be carried out upon material other than topsoil, rock or artificial hard material unless otherwise stated in item descriptions.</p>	<p>C3 Items for <i>filling</i> shall be deemed to include compaction.</p>	<p>A7 Item descriptions for <i>excavation ancillaries</i> in connection with excavation by dredging shall be so described.</p> <p>A8 Item descriptions for <i>trimming of excavated surfaces and preparation of excavated surfaces</i> shall identify surfaces which are:</p> <p>(a) inclined at an angle of 10°-45° to the horizontal</p> <p>(b) inclined at an angle of 45°-90° to the horizontal</p> <p>(c) vertical.</p> <p>A9 Where material is for disposal on the Site the location of the disposal areas shall be stated in item descriptions for <i>disposal of excavated material</i>.</p>
<p>M16 <i>Filling of excavations around completed structures</i> shall be measured only to the extent that the volume filled is also measured as excavation in accordance with rule M6.</p> <p>M17 Where <i>filling to form temporary roads</i> is subsequently approved by the Engineer for incorporation into permanent filling the volume placed shall not be deducted from the measurement of filling.</p> <p>M18 Additional <i>filling</i> necessitated by settlement of or penetration into underlying material shall be measured only to the extent that its depth exceeds 75 mm.</p> <p>M19 The volume of <i>imported filling material</i> measured shall be the difference between the net volume of filling and the net volume of excavated material derived from work within classes E and F used for filling.</p> <p>M20 Where <i>rock filling</i> is deposited into soft areas the volume shall be measured in the transport vehicles at the place of deposition.</p> <p>M21 Where <i>filling</i> is to be deposited below water, and the quantity cannot be measured satisfactorily by any other means, its volume shall be measured in the transport vehicles at the place of deposition.</p>	<p>D6 <i>Filling material</i> shall be deemed to be <i>non-selected excavated material other than topsoil or rock</i>, unless otherwise stated in item descriptions.</p> <p>D7 <i>Filling material</i> shall be classed as <i>excavated rock</i> only where the use of rock as filling at stated locations is expressly required.</p> <p>D8 <i>Filling</i> shall be classed as to <i>stated depth or thickness</i> where material is provided of uniform total compacted depth or thickness such as in drainage blankets, topsoiling, pitching and beaching. Bulk filling shall not be classed as to <i>stated depth or thickness</i> notwithstanding that it may be compacted in separate layers of material of stated thickness.</p>	<p>C3 Items for <i>filling</i> shall be deemed to include compaction.</p>	<p>A10 The materials shall be identified in item descriptions for <i>filling with imported material</i>.</p> <p>A11 Where different compaction requirements are specified for the same filling material they shall be stated in item descriptions for <i>filling</i>.</p> <p>A12 Where the rate of deposition of <i>filling material</i> is limited the limitation shall be stated in item descriptions for <i>filling</i>.</p> <p>A13 The materials shall be identified in item descriptions for <i>filling to stated depth or thickness</i>.</p> <p>A14 Item descriptions for <i>filling to stated depth or thickness</i> shall identify work upon surfaces which are:</p> <p>(a) inclined at an angle of 10°-45° to the horizontal</p> <p>(b) inclined at an angle of 45°-90° to the horizontal</p> <p>(c) vertical.</p>

CLASS E

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
7 Filling ancillaries	1 Trimming of filled surfaces m^2 2 Preparation of filled surfaces m^2	1 Topsoil 2 Material other than topsoil, rock or artificial hard material 3 Rock 4 Stated artificial hard material
	3 Geotextiles m^2	
8 Landscaping	1 Turfing m^2 2 Hydraulic mulch grass seeding m^2 3 Other grass seeding m^2 4 Plants, stated species and size nr 5 Shrubs, stated species and size nr 6 Trees, stated species and size nr	
	7 Hedges, stated species, size and spacing m	1 Single row 2 Double row

CLASS E

(see rule at head of class on page 35)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M22 <i>Trimming of filled surfaces</i> shall be measured to surfaces which are to receive no Permanent Works whether trimming is expressly required or not.</p>	<p>D9 <i>Trimming and preparation</i> shall be deemed to be carried out upon material other than topsoil, rock or artificial hard material unless otherwise stated in item descriptions.</p>		<p>A15 Item descriptions for <i>filling ancillaries</i> shall identify work upon surfaces which are:</p> <p>(a) inclined at an angle of 10°-45° to the horizontal (b) inclined at an angle of 45°-90° to the horizontal (c) vertical.</p> <p>A16 The type and grade of material shall be stated in item descriptions for <i>geotextiles</i>.</p>
<p>M23 <i>Preparation of filled surfaces</i> shall be measured to surfaces which are to receive Permanent Works whether preparation is expressly required or not except surfaces which are to receive filling or landscaping and surfaces for which formwork is measured.</p>		<p>C4 Items for <i>landscaping</i> shall be deemed to include fertilizing, trimming and preparation of surfaces.</p>	<p>A17 Where <i>turfing</i> is pegged or wired item descriptions shall so state.</p> <p>A18 Item descriptions for <i>turfing and grass seeding</i> shall identify work upon surfaces which are inclined at an angle exceeding 10° to the horizontal.</p>
<p>M24 The area of additional <i>geotextiles</i> in laps shall not be measured.</p>			
<p>M25 The lengths of <i>beiges</i> measured shall be their developed lengths along centre lines.</p>			

CLASS F: IN SITU CONCRETE

Excludes: In situ concrete for:
 capping of boreholes (included in class B)
 diaphragm walls (included in class C)
 excavation ancillaries (included in class E)
 granolithic and other applied finishes (included in class G)
 drainage and pipework (included in classes K and L)
 piles (included in classes P and Q)
 roads, pavings and kerbs (included in class R)
 tunnel and shaft linings (included in class T)
 foundations for fences and gates (included in class X)

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
1	<i>Provision of concrete</i> Standard mix	m ³	<ol style="list-style-type: none"> 1 ST1 2 ST2 3 ST3 4 ST4 5 ST5
			<p><i>Cement to BS 12 or BS 146</i></p> <ol style="list-style-type: none"> 1 10 mm aggregate 2 14 mm aggregate 3 20 mm aggregate 4 40 mm aggregate <p><i>Other stated cement</i></p> <ol style="list-style-type: none"> 5 10 mm aggregate 6 14 mm aggregate 7 20 mm aggregate 8 40 mm aggregate
2	<i>Provision of concrete</i> Designed mix	m ³	<ol style="list-style-type: none"> 1 Grade: C7.5 2 C10 3 C15 4 C20 5 C25 6 C30 7 C35 8 C40
3	<i>Provision of concrete</i> Designed mix	m ³	<ol style="list-style-type: none"> 1 Grade: F3 2 F4 3 F5
4	<i>Provision of concrete</i> Prescribed mix	m ³	
5	<i>Placing of concrete</i> Mass	m ³	<ol style="list-style-type: none"> 1 Blinding 2 Bases, footings, pile caps and ground slabs 3 Suspended slabs 4 Walls
6	Reinforced	m ³	<ol style="list-style-type: none"> 1 Thickness: not exceeding 150 mm 2 150–300 mm 3 300–500 mm 4 exceeding 500 mm
7	Prestressed	m ³	<ol style="list-style-type: none"> 5 Columns and piers 6 Beams 7 Casing to metal sections
			<ol style="list-style-type: none"> 1 Cross-sectional area: not exceeding 0.03 m² 2 0.03–0.1 m² 3 0.1–0.25 m² 4 0.25–1 m² 5 exceeding 1 m² 6 Special beam sections
			<ol style="list-style-type: none"> 8 Other concrete forms

CLASS F

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The volume of concrete measured shall include that occupied by:</p> <ul style="list-style-type: none"> (a) reinforcement and other metal sections (b) prestressing components (c) cast-in components each not exceeding 0.1 m² in volume (d) rebates, grooves, throats, fillets, channfers or internal splays each not exceeding 0.01 m² in cross-sectional area (e) pockets and holes which are defined as large or small voids in accordance with rule D3 of class G (f) joints or joint components between adjacent volumes of in situ concrete. <p>M2 The volume of concrete measured shall exclude that of nibs or external splays each not exceeding 0.01 m² in cross-sectional area.</p>			
	<p>D1 Items for provision of concrete shall be classified in accordance with BS 5328.</p> <p>D2 A concrete mix shall be classed as a <i>standard mix</i> where the mix is to be selected by the Contractor from the restricted list given in section 4 of BS 5328: Part 2.</p> <p>D3 A concrete mix shall be classed as a <i>designed mix</i> where the performance is stated in the Contract and the mix proportions are to be selected by the Contractor.</p> <p>D4 A concrete mix shall be classed as a <i>prescribed mix</i> where the mix proportions are stated in the Contract.</p>		<p>A1 The specification of the concrete mix in accordance with BS 5328 shall be stated in item descriptions for provision of concrete unless a mix reference is stated for which the specification is given elsewhere in the Contract.</p>
<p>M3 Columns and piers integral with a wall shall be measured as part of the wall, except where expressly required to be cast separately.</p> <p>M4 Beams integral with a slab shall be measured as part of the slab, except where expressly required to be cast separately.</p>	<p>D5 Prestressed concrete which is also reinforced shall be classed as <i>prestressed concrete</i>.</p> <p>D6 The thickness used for classification of <i>blinding</i> shall be the minimum thickness.</p> <p>D7 The thickness used for classification of <i>ground slabs</i>, <i>suspended slabs</i> and <i>walls</i> shall exclude the additional thickness of integral beams, columns, piers and other projections.</p> <p>D8 Concrete in <i>suspended slabs</i> and <i>walls</i> less than 1 m wide or long shall be classed as concrete in <i>beams</i> and <i>columns</i> respectively.</p> <p>D9 Beams shall be classed as <i>special beam sections</i> where their cross-section profiles are rectangular or approximately rectangular over less than 2/5 of their length or where they are of box or other composite section.</p>		<p>A2 Item descriptions for placing of concrete which is expressly required to be placed against an excavated surface (other than blinding) shall so state.</p> <p>A3 The cross-sectional dimensions of <i>special beam sections</i> shall be stated in item descriptions, except where a beam type or mark number is stated for which dimensions are given on the Drawings.</p> <p>A4 Item descriptions for components classed as <i>other concrete forms</i> shall identify the component and include one of the following:</p> <ul style="list-style-type: none"> (a) the principal dimensions of the concrete component (b) a type or mark number of a concrete component for which principal dimensions are given on the Drawings (c) a statement locating a concrete component for which principal dimensions are given on the Drawings

E

In accordance with paragraph 5.10 the location of concrete members in the Works may be stated in item descriptions for placing of concrete members and characteristics may affect the method and rate of placing concrete.

CLASS G: CONCRETE ANCILLARIES

Includes: Formwork for in situ concrete
 Reinforcement for in situ concrete
 Joints in in situ concrete
 Post-tensioned prestressing
 Accessories for in situ concrete

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Formwork: rough finish 2 fair finish 3 other stated finish 4 stated surface features	1 Plane horizontal 2 Plane sloping 3 Plane battered 4 Plane vertical 5 Curved to one radius in one plane	1 Width: not exceeding 0.1 m 2 0.1-0.2 m 3 0.2-0.4 m 4 0.4-1.22 m 5 exceeding 1.22 m
	6 Other curved m ²	
	7 For voids nr	1 Small void depth: not exceeding 0.5 m 2 0.5-1 m 3 1-2 m 4 stated exceeding 2 m 5 Large void depth: not exceeding 0.5 m 6 0.5-1 m 7 1-2 m 8 stated exceeding 2 m
	8 For concrete components of constant cross-section m	1 Beams 2 Columns 3 Walls 4 Other members 5 Projections 6 Intrusions
5 Reinforcement	1 Plain round steel bars to BS 4449 t 2 Deformed high yield steel bars to BS 4449 t 3 Stainless steel bars of stated quality t 4 Reinforcing bars of other stated material t	1 Nominal size: 6 mm 2 8 mm 3 10 mm 4 12 mm 5 15 mm 6 20 mm 7 25 mm 8 32 mm or greater
	5 Special joints nr	
	6 Steel fabric to BS 4483 m ² 7 Fabric of other stated material m ²	1 Nominal mass: not exceeding 2 kg/m ² 2 2-3 kg/m ² 3 3-4 kg/m ² 4 4-5 kg/m ² 5 5-6 kg/m ² 6 6-7 kg/m ² 7 7-8 kg/m ² 8 stated exceeding 8 kg/m ²

CLASS G

- Excludes:** Reinforcement in diaphragm walls (included in class C)
 Pre-tensioned prestressing (included in class H)
 Formwork and reinforcement in precast concrete (included in class H)
 Formwork and reinforcement ancillary to drainage and pipework (included in classes K and L)
 Formwork and reinforcement in piles (included in classes P and Q)
 Formwork and reinforcement for concrete roads and pavings (included in class R)
 Formwork for tunnel and shaft linings (included in class T)
 Formwork for foundations for fences and gates (included in class X)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES																					
<p>M1 Formwork shall be measured for surfaces of in situ concrete which require temporary support during casting except where otherwise stated in CESMM3.</p> <p>M2 Formwork shall not be measured for the following:</p> <p>(a) edges of blinding concrete not exceeding 0.2 m wide joints and associated rebates and grooves</p> <p>(b) temporary surfaces formed at the discretion of the Contractor</p> <p>(c) surfaces of concrete which are expressly required to be cast against an excavated surface</p> <p>(d) surfaces of concrete which are cast against excavated surfaces inclined at an angle less than 45° to the horizontal.</p> <p>M3 Formwork to upper surfaces of concrete shall be measured to surfaces inclined at an angle exceeding 15° to the horizontal and to other upper surfaces for which formwork is expressly required.</p> <p>M4 Formwork for the surfaces of voids larger than those classed as large voids in accordance with rule D3 shall be measured as set out in this class for formwork generally.</p> <p>M5 Formwork for the surfaces of projections and intrusions exceeding 0.01 m² in cross-sectional area shall be measured as set out in this class for formwork generally.</p> <p>M6 The area of formwork measured shall include the area of formwork obscured by:</p> <p>(a) forms for large and small voids</p> <p>(b) forms for projections and intrusions</p> <p>(c) inserts</p> <p>M7 The mass of steel reinforcement shall be taken as 0.785 kg/m per 100 mm² of cross-section (7.85 t/m³). The mass of other reinforcing materials shall be taken as stated in the Contract.</p> <p>M8 The mass of reinforcement measured shall include the mass of steel supports to top reinforcement.</p> <p>M9 The area of additional fabric in laps shall not be measured.</p>	<p>D1 Plane formwork shall be classified according to its angle of inclination as follows:</p> <table border="1"> <thead> <tr> <th>Class</th> <th>Angle of inclination to the vertical</th> </tr> </thead> <tbody> <tr> <td>Horizontal</td> <td>0°-30°</td> </tr> <tr> <td>Sloping</td> <td>10°-85°</td> </tr> <tr> <td>Battered</td> <td>0°-10°</td> </tr> <tr> <td>Vertical</td> <td>0°</td> </tr> </tbody> </table> <p>D2 Formwork shall be deemed to be for plane areas and to exceed 1.22 m wide, unless otherwise stated.</p> <p>D3 The classification of large and small voids shall be as follows:</p> <table border="1"> <thead> <tr> <th rowspan="2">Class</th> <th colspan="2">Maximum cross-section</th> </tr> <tr> <th>Circular voids (isometric)</th> <th>Other voids (area)</th> </tr> </thead> <tbody> <tr> <td>Large</td> <td>0.35-0.7 m</td> <td>0.1-0.5 m²</td> </tr> <tr> <td>Small</td> <td>Not exceeding 0.35 m</td> <td>Not exceeding 0.1 m²</td> </tr> </tbody> </table> <p>The depths of voids shall be measured perpendicularly to the adjacent surface of concrete.</p> <p>D4 Nibs and external spalls not exceeding 0.01 m² in cross-sectional area shall be classed as projections.</p> <p>D5 Reobates, grooves, internal spalls, throats, filllets and chamfers not exceeding 0.01 m² in cross-sectional area shall be classed as intrusions.</p> <p>D6 The nominal size stated in item descriptions for bar reinforcement shall be the cross-sectional size defined in BS 4449.</p> <p>D7 Welded, swaged or screwed sleeve joints in reinforcing bars shall be classed as special joints.</p>	Class	Angle of inclination to the vertical	Horizontal	0°-30°	Sloping	10°-85°	Battered	0°-10°	Vertical	0°	Class	Maximum cross-section		Circular voids (isometric)	Other voids (area)	Large	0.35-0.7 m	0.1-0.5 m ²	Small	Not exceeding 0.35 m	Not exceeding 0.1 m ²	<p>C1 Items for reinforcement shall be deemed to include supporting reinforcement other than steel supports to top reinforcement.</p>	<p>A1 Formwork left in situ shall be so described in item descriptions for formwork.</p> <p>A2 Item descriptions for formwork which is to upper surfaces shall so state, except where the surfaces are inclined at an angle not exceeding 10° to the vertical.</p> <p>A3 Item descriptions for formwork shall state where the formwork is to blinding concrete.</p> <p>A4 Radii of curved formwork shall be stated in item descriptions as follows:</p> <p>(a) to one radius in one plane (cylindrical), radius stated</p> <p>(b) to one radius in two planes (spherical), radius stated</p> <p>(c) varying radius (conical), maximum and minimum radii stated.</p> <p>A5 Item descriptions for formwork for concrete components of constant cross-section, other than projections and intrusions, shall state the principal cross-sectional dimensions of the component and its mark number, location or other unique identifying feature.</p> <p>A6 Formwork for curved concrete components of constant cross-section shall be so described stating the radii.</p>
Class	Angle of inclination to the vertical																							
Horizontal	0°-30°																							
Sloping	10°-85°																							
Battered	0°-10°																							
Vertical	0°																							
Class	Maximum cross-section																							
	Circular voids (isometric)	Other voids (area)																						
Large	0.35-0.7 m	0.1-0.5 m ²																						
Small	Not exceeding 0.35 m	Not exceeding 0.1 m ²																						
			<p>A7 Item descriptions for bar reinforcement shall state the lengths of bars to the next higher multiples of 3 m where they exceed 12 m before bending.</p> <p>A8 Item descriptions for special joints shall state the type of joint and type and size of reinforcing bar.</p> <p>A9 Item descriptions for steel fabric to BS 4483 shall state the fabric reference in accordance with BS 4483 or the wire and mesh arrangement in accordance with BS 4466.</p> <p>A10 Item descriptions for fabric of other stated material shall state the sizes and nominal mass per square metre.</p>																					

NOTE

Formwork may be measured as follows:

CLASS G

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
6 Joints	1 Open surface plain m^2	1 Average width: not exceeding 0.5 m
	2 Open surface with filler m^2	2 0.5-1 m
	3 Formed surface plain m^2	3 stated exceeding 1 m
	4 Formed surface with filler m^2	
	5 Plastics or rubber waterstops m	1 Average width: not exceeding 150 mm.
	6 Meta. waterstops m	2 150-200 mm
		3 200-300 mm
		4 stated exceeding 300 mm
	7 Sealed rebates or grooves m	
	8 Dowels nr	1 Plain or greased 2 Sleeved or capped
7 Post-tensioned prestressing nr	1 Horizontal internal tendons in in situ concrete	1 Length: not exceeding 5 m
	2 Inclined or vertical internal tendons in in situ concrete	2 5-7 m
	3 Horizontal internal tendons in precast concrete	3 7-10 m
	4 Inclined or vertical internal tendons in precast concrete	4 10-15 m
		5 15-20 m
	6 20-25 m	
	7 25-30 m	
	8 stated exceeding 30 m	
	5 External jacking operations	
8 Concrete accessories	1 Finishing of top surfaces m^2	1 Wood float 2 Steel trowel 3 Other stated surface treatment 4 Granolithic finish 5 Other stated applied finish
	2 Finishing of formed surfaces m^2	1 Aggregate exposure using retarder 2 Bush hammering 3 Other stated surface treatment carried out after striking formwork
	3 Inserts	1 Linear inserts m 2 Other inserts nr
	4 Grouting under plates nr	1 Area: not exceeding 0.1 m^2 2 0.1-0.5 m^2 3 0.5-1 m^2 4 stated exceeding 1 m^2

CLASS G

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M10 Joints shall be measured only where they are at locations where joints are expressly required.</p> <p>M11 The widths of joints shall be measured between the outer surfaces of concrete with no deducting or addition for widths or depths occupied by rebates, grooves, fillers or waterstops. The lengths of waterstops shall be measured along their centre lines.</p>	<p>D8 Joints for which temporary support of the whole surface area of concrete is required during casting shall be classed as <i>formed surface joints</i>. Other joints shall be classed as <i>open surface joints</i>.</p>	<p>C2 Items for <i>open surface and formed surface joints</i> shall be deemed to include intermediate surface treatment where expressly required.</p> <p>C3 Items for joints shall be deemed to include formwork.</p> <p>C4 Items for waterstops shall be deemed to include cutting and joining of waterstops and provision of special fittings at angles and junctions.</p>	<p>A11 The dimensions and nature of components shall be stated in item descriptions for joints.</p>
<p>M12 Prestressing shall be measured by the number of tendons where tendons are used and by the number of external jacking operations where stress is induced by jacking only.</p>	<p>D9 Profiled tendons in horizontal components shall be classed as <i>horizontal tendons</i>.</p> <p>D10 The lengths of tendons used for classification shall be their developed lengths between the outer faces of anchorages.</p>	<p>C5 Items for prestressing shall be deemed to include ducts, grouting and other components and tasks ancillary to prestressing.</p>	<p>A12 Item descriptions for prestressing shall identify the concrete component to be stressed and state the composition of the tendon and particulars of the anchorage.</p>
<p>M13 Surface treatments shall not be measured to surfaces formed at the Contractor's discretion.</p> <p>M14 The areas of tops of walls and other surfaces which are not given separate finishing treatment shall not be measured as finishing of top surfaces.</p> <p>M15 No deduction from the areas measured for finishing shall be made for holes and openings in the finished surfaces each not exceeding 0.5 m².</p>		<p>C6 Items for <i>granolithic and other stated applied finish</i> shall be deemed to include materials, surface treatment, joints and formwork.</p>	<p>A13 The materials, thicknesses and surface treatments of <i>granolithic and other stated applied finish</i> shall be stated in item descriptions.</p>
<p>M15 Where inserts are expressly required to be grouted into preformed openings the formwork shall be measured.</p>	<p>D11 Components cast or grouted into in situ concrete except reinforcement, prestressing and jointing materials shall be classed as <i>inserts</i>.</p>	<p>C7 Items for inserts shall be deemed to include their supply unless otherwise stated.</p>	<p>A14 Item descriptions for inserts shall identify the components to be cast or grouted in and state their principal dimensions.</p> <p>A15 Item descriptions for inserts shall identify:</p> <ul style="list-style-type: none"> (a) those which project from one surface of the concrete (b) those which project from two surfaces of the concrete (c) those which are totally within the concrete volume. <p>A16 Where inserts are expressly required to be grouted into preformed openings in concrete item descriptions shall so state. Materials for grouting and sizes of openings shall be stated.</p>
			<p>A17 Materials shall be stated in item descriptions for grouting under plates.</p>

NOTE

Similar inserts which vary in size may be added together and classified by size within ranges.

CLASS H: PRECAST CONCRETE

Includes: Manufacture, erection, joining and fixing of precast concrete units

Excludes: Post-tensioned prestressing (included in class G)
 Precast concrete pipework (included in classes I and J)
 Precast concrete manholes, catchpits and gullies (included in class K)
 Precast concrete piles (included in classes P and Q)
 Precast concrete paving, kerbs and traffic sign supports (included in class R)
 Precast concrete tunnel linings (included in class T)
 Precast concrete blockwork (included in class U)
 Precast concrete fencing (included in class X)

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
1 Beams	nr	1 Length: not exceeding 5 m	1 Mass. not exceeding 250 kg
2 Prestressed pre-tensioned beams	nr	2 5-7 m	2 250-500 kg
3 Prestressed post-tensioned beams	nr	3 7-10 m	3 500 kg-1 t
4 Columns	nr	4 10-15 m	4 1-2 t
		5 15-20 m	5 2-5 t
		6 20-30 m	6 5-10 t
		7 exceeding 30 m	7 10-20 t
			8 stated exceeding 20 t
5 Slabs	nr	1 Area: not exceeding 1 m ²	
		2 1-4 m ²	
		3 4-15 m ²	
		4 15-50 m ²	
		5 exceeding 50 m ²	
6 Segmental units	nr		
7 Units for subways, culverts and ducts	m		
8 Copings, sills and weir blocks	m	1 Cross-sectional area: not exceeding 0.1 m ²	
		2 0.1-0.5 m ²	
		3 0.5-1 m ²	
		4 exceeding 1 m ²	

CLASS H

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The length measured for <i>units for subways, culverts and ducts</i> and for <i>copings, sills and weir blocks</i> shall be the total length of identical units.</p>	<p>D1 The mass used for classification in the third division shall be the mass of each unit.</p> <p>D2 Concrete components which are cast other than in their final position shall generally be classed as <i>precast concrete units</i>.</p> <p>D3 Where site precasting of units is adopted for reasons other than to obtain multiple use of formwork and the nature of the work is characteristic of in situ concrete, but involves the movement of the cast units into their final positions, the units shall be classed as <i>in situ concrete</i> and items given in class A for the Temporary Works associated with the movement of the units.</p>	<p>C1 Items for precast concrete shall be deemed to include reinforcement, formwork, joints and finishes.</p>	<p>A1 The position in the Works and specification of the concrete to be used in each type of precast unit shall be stated in item descriptions.</p> <p>A2 Item descriptions shall state the mark or type number of each precast concrete unit. Units with different dimensions shall be given different mark or type numbers.</p> <p>A3 Particulars of tendons and prestressing shall be stated in item descriptions for prestressed pre-tensioned units.</p> <p>A4 The cross-section type and principal dimensions shall be stated in item descriptions for <i>beams, columns, segmental units, units for subways, culverts, ducts, copings, sills and weir blocks</i>.</p> <p>A5 The average thickness shall be stated in item descriptions for <i>slabs</i>.</p> <p>A6 The mass per metre shall be stated in item descriptions for <i>units for subways, culverts, ducts, copings, sills and weir blocks</i>.</p>

CLASS I

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The Commencing Surface adopted in the preparation of the Bill of Quantities shall be adopted for the measurement of the completed work.</p> <p>M2 Backfilling of trenches shall not be measured except as set out in class K for filling of French and rubble drains and in class L for backfilling with material other than that excavated from the trenches.</p> <p>M3 Lengths of pipes shall be measured along their centre lines. Lengths of pipes in trenches shall include lengths occupied by fittings and valves and exclude lengths occupied by pipes and fittings comprising backdrops to manholes. Lengths of pipes not in trenches shall exclude lengths occupied by fittings and valves.</p> <p>M4 Additional items shall be given in classes K and L for work in connection with pipes not in trenches other than the provision, laying and jointing of pipes.</p> <p>M5 Lengths of pipes entering manholes and other chambers shall be measured to the inside surfaces of the chambers except that pipes and fittings comprising backdrops to manholes shall be included in items for manholes measured in class K.</p>	<p>D1 Pipes not in trenches shall include pipes suspended or supported above the ground or other surface, pipes in roadings, tunnels or shafts, pipes installed by thrust boring and pipe jacking and pipes laid within volumes measured separately for excavation.</p> <p>D2 Pipes not in trenches shall be classed as such only where pipes are expressly required not to be laid in trenches.</p> <p>D3 Depths used for classification of pipes in trenches shall be measured from the Commencing Surface to the inverts of the pipes.</p>	<p>C1 Items for pipes shall be deemed to include the supply of all materials by the Contractor unless otherwise stated. Items shall be deemed to include pipe cutting.</p> <p>C2 Items for pipes in trenches shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling and removal of dead services except to the extent that such work is included in classes J, K and L.</p>	<p>A1 The location or type of pipework in each item or group of items shall be stated in item descriptions so that the pipe runs included can be identified by reference to the Drawings.</p> <p>A2 The materials, joint types, nominal bore and lining requirements of pipes shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities.</p> <p>A3 Item descriptions for pipes not in trenches shall distinguish between the different categories of pipes listed in rule D1.</p> <p>A4 The Commencing Surface shall be identified in the description of each item for work involving excavation for which the Commencing Surface is not also the Original Surface.</p> <p>A5 Where more than one pipe is expressly required to be laid in one trench the item descriptions for each pipe shall so state and also identify the pipe run. Where pipes are laid in French or rubble drains item descriptions shall so state.</p> <p>A6 Trench depths exceeding 4 m shall be stated in item descriptions to the next higher multiple of 0.5 m.</p> <p>A7 Item descriptions shall identify separately excavation which is expressly required to be carried out by hand.</p>

CLASS J: PIPEWORK — FITTINGS AND VALVES

Includes: Fittings and valves for pipework
Excludes: Work included in classes I, K, L and Y
 Piped building services (included in class Z)

FIRST DIVISION		SECOND DIVISION		THIRD DIVISION	
1	Clay pipe fittings	nr	1 Bends	1	Nominal bore: not exceeding 200 mm
2	Concrete pipe fittings	nr	2 Junctions and branches	2	200–300 mm
3	Iron or steel pipe fittings	nr	3 Tapers	3	300–600 mm
4	Polyvinyl chloride pipe fittings	nr	4 Double collars	4	600–900 mm
5	Glass reinforced plastic pipe fittings	nr	5 Adaptors	5	900–1200 mm
6	High density polyethylene pipe fittings	nr	6 Glands	6	1200–1500 mm
7	Medium density polyethylene pipe fittings	nr	7 Bellmouths	7	1500–1800 mm
			8 Straight specials	8	exceeding 1800 mm
8	Valves and penstocks	nr	1 Gate valves: hand operated		
			2 power operated		
			3 Non-return valves		
			4 Butterfly valves: hand operated		
			5 power operated		
			6 Air valves		
			7 Pressure reducing valves		
			8 Penstocks		

CLASS J

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
		<p>C1 Items for fittings and valves shall be deemed to include the supply of materials by the Contractor, unless otherwise stated.</p> <p>C2 Items for fittings and valves shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling and removal of dead services except to the extent that such work is included in classes I, K and L.</p>	
<p>M1 Pipe fittings comprising backdrops to manholes shall be included in the items for manholes measured in class K.</p> <p>M2 Straight specials shall be measured only where they are expressly required. Straight specials shall not be measured where they are necessitated only by the layout of the work. Pipe runs between manholes, chambers and other structures whose lengths are not an exact multiple of a standard pipe length shall be deemed to require straight specials only if they are expressly required as rocker pipes.</p>	<p>D1 Pipe fittings on pipes of different nominal bores shall be classified in the third division according to the nominal bore of the largest pipe.</p> <p>D2 A straight special is a length of pipe either cut to length or made to order.</p>	<p>C3 Items for straight specials shall be deemed to include cutting.</p>	<p>A1 The materials, joint types, nominal bores and lining requirements of pipe fittings shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities. Fittings with puddle flanges shall be so described.</p> <p>A2 Item descriptions for pipe fittings to cast iron or spun iron pipework of nominal bore exceeding 300 mm and to all steel pipework shall state the principal dimensions of each fitting.</p> <p>A3 Vertical bends in pipework of which the nominal bore exceeds 300 mm shall be so described.</p> <p>A4 Fittings to pipework not in trenches shall be so described.</p> <p>A5 Fittings to reticulated water mains measured in class Y shall be so described.</p>
			<p>A6 The materials, nominal bores and any additional requirements such as joints, draincocks, extension spindles and brackets shall be stated in item descriptions for valves and penstocks and reference given to applicable British Standard specifications and specified qualities.</p> <p>A7 Valves and penstocks to reticulated water mains measured in class Y shall be so described.</p>

CLASS K: PIPEWORK—MANHOLES AND PIPEWORK ANCILLARIES

- Includes:** Manholes and other chambers, ducts, culverts, crossings and reinstatement, other ancillaries as listed
Excludes: Work included in classes I, J, L and Y
 Ducted building services (included in class Z)

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
1 Manholes	nr	1 Brick 2 Brick with backdrop 3 In situ concrete 4 In situ concrete with backdrop 5 Precast concrete 6 Precast concrete with backdrop	1 Depth: not exceeding 1.5 m 2 1.5-2 m 3 2-2.5 m 4 2.5-3 m 5 3-3.5 m 6 3.5-4 m 7 stated exceeding 4 m
2 Other stated chambers	nr	1 Brick 3 In situ concrete 5 Precast concrete	
3 Gullies	nr	1 Clay 2 Clay trapped 3 In situ concrete 4 In situ concrete trapped 5 Precast concrete 6 Precast concrete trapped 7 Plastics 8 Plastics trapped	
4 French drains, rubble drains, ditches and trenches		1 Filling French and rubble drains with graded material m ³ 2 Filling French and rubble drains with rubble m ³ 3 Trenches for unpiped rubble drains m 4 Rectangular section ditches: unlined m 5 lined m 6 Vee section ditches: unlined m 7 lined m 8 Trenches for pipes or cables not to be laid by the Contractor m	1 Cross-sectional area: not exceeding 0.25 m ² 2 0.25-0.5 m ² 3 0.5-0.75 m ² 4 0.75-1 m ² 5 1-1.5 m ² 6 1.5-2 m ² 7 2-3 m ² 8 stated exceeding 3 m ²
5 Ducts and metal culverts	m	1 Cable ducts: 1 way 2 2 way 3 3 way 4 stated number of ways exceeding 3 5 Sectional corrugated metal culverts, nominal internal diameter: not exceeding 0.5 m 6 0.5-1 m 7 1-1.5 m 8 exceeding 1.5 m	1 Not in trenches 2 In trenches, depth: not exceeding 1.5 m 3 1.5-2 m 4 2-2.5 m 5 2.5-3 m 6 3-3.5 m 7 3.5-4 m 8 exceeding 4 m

CLASS K

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
	<p>D1 The centre line for multiple pipes, ducts or culverts shall be the line equidistant between the inside faces of the outer pipe walls.</p>	<p>C1 Items for work in this class shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation backfilling and removal of dead services, except to the extent that such work is included in classes I, J and L.</p> <p>C2 Items for work in this class shall be deemed to include concrete, reinforcement, formwork, joints and finishes.</p>	
	<p>D2 The depths of manholes and other chambers shall be measured from the tops of covers to channel inverts or tops of base slabs, whichever is the lower.</p> <p>D3 Drawpits shall be classed as other stated chambers</p>	<p>C3 Item for <i>manholes, other stated chambers and gullies</i> shall be deemed to include all items of metalwork and pipework, other than valves, which occur within or at the surface of the item.</p> <p>C4 Items for <i>manholes</i> with backdrops shall be deemed to include the pipework and associated fittings comprising the backdrop.</p>	<p>A1 Type or mark numbers shall be stated in item descriptions for <i>manholes, other stated chambers and gullies</i> of which details are given elsewhere in the Contract.</p> <p>A2 Types and loading duties of covers shall be stated in item descriptions for <i>manholes, other stated chambers and gullies</i>.</p> <p>A3 Item descriptions for <i>manholes, other stated chambers and gullies</i> shall identify separately those which are expressly required to be excavated by hand.</p>
<p>M1 Excavation and pipe laying for piped <i>French and rubble drains</i> are measured in class I.</p>			<p>A4 The nature of the filling material shall be stated in item descriptions for <i>filling French and rubble drains</i>.</p>
<p>M2 The cross-sectional areas of <i>lined ditches</i> shall be measured to the Excavated Surface.</p>			<p>A5 Materials and dimensions of linings to ditches shall be stated in item descriptions.</p>
<p>M3 The rules in class I for pipes shall also apply to <i>ducts and metal culverts</i> in this class except that the lengths measured for ducts and metal culverts not in trenches shall include lengths occupied by fittings.</p>	<p>D4 Non-circular <i>metal culverts</i> shall be classified by their maximum nominal internal cross-sectional dimension</p> <p>D5 The rules in class I for pipes shall also apply to <i>ducts and metal culverts</i> in this class.</p>	<p>C5 Items for <i>ducts and metal culverts</i> shall be deemed to include cutting and fittings</p>	<p>A6 The rules in class I for pipes shall also apply to <i>ducts and metal culverts</i> in this class.</p>

NOTE
 Manholes and other chambers may be measured in detail as set out in other classes of CESMMS.

CLASS K

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
6 Crossings	nr	1 River, stream or canal, width: 1--3 m 3--10 m 3 stated exceeding 10 m 4 Hedge 5 Wall 6 Fence 7 Sewer or drain 8 Other stated underground service	1 Pipe bore: not exceeding 300 mm 2 300--900 mm 3 900--1800 mm 4 stated exceeding 1800 mm
7 Reinstatement	m	1 Breaking up and temporary reinstatement of roads 2 Breaking up and temporary reinstatement of footpaths 3 Breaking up, temporary and permanent reinstatement of roads 4 Breaking up, temporary and permanent reinstatement of footpaths 5 Reinstatement of land	1 Pipe bore: not exceeding 300 mm 2 300--900 mm 3 900--1800 mm 4 stated exceeding 1800 mm
		6 Strip topsoil from easement and reinstata	
8 Other pipework ancillaries		1 Reinstatement of field drains m 2 Marker posts nr 3 Timber supports left in excavations m ² 4 Metal supports left in excavations m ²	
		5 Connections to existing manholes and other chambers nr 6 Connections to existing pipes, ducts and culverts nr	1 Pipe bore: not exceeding 200 mm 2 200--300 mm 3 300--600 mm 4 600--900 mm 5 900--1200 mm 6 1200--1500 mm 7 1500--1800 mm 8 stated exceeding 1800 mm

CLASS K

(see rules at head of class on page 53)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M4 Crossings shall be measured for pipes, ducts and metal culverts.</p> <p>M5 Crossings of streams shall be measured only where their width exceeds 1 m.</p>	<p>D6 River, stream and canal crossings shall be classified by their widths measured along pipe, duct or culvert centre lines when the water surface is at the level for the higher level of fluctuation if applicable; shown on the drawing to which reference is given in the Preamble in accordance with paragraph 5.20.</p> <p>D7 The dimension used for classification of bore in the third division shall be the maximum nominal distance between the inside faces of the outer walls of the pipe, duct or culvert to be installed.</p>	<p>C6 Items for crossings shall be deemed to include reinstatement unless otherwise stated.</p>	<p>A7 Where linings to rivers, streams or canals are to be broken through and reinstated the type of lining shall be stated in item descriptions.</p>
<p>M6 Reinstatement shall be measured for pipes, ducts and metal culverts.</p> <p>M7 Lengths of reinstatement shall be measured along centre lines and shall include lengths occupied by manholes and other chambers.</p> <p>M8 Strip topsoil from easement and reinstatement shall be measured only where it is expressly required that a width of ground greater than the nominal trench width defined in accordance with rule D1 in class L is to be stripped of topsoil before trench excavation and subsequently reinstated.</p>	<p>D7 The dimension used for classification of bore in the third division shall be the maximum nominal distance between the inside faces of the outer walls of the pipe, duct or culvert to be installed.</p> <p>D8 Crossings of roads and paths shall be classed as breaking up and reinstatement of roads and paths.</p>	<p>C7 Additional reinstatement shall be deemed to be included in the items for manholes and other chambers.</p> <p>C8 Removal and reinstatement of kerbs and channels shall be deemed to be included in the items for breaking up and reinstatement of roads and footpaths.</p> <p>C9 Items for strip topsoil from easement and reinstatement shall be deemed to include storing and protecting topsoil and reinstatement of land.</p>	<p>A8 Types and depths of surfacing, including base and sub-base courses, shall be stated in item descriptions for breaking up and reinstatement of roads and footpaths.</p> <p>A9 Item descriptions for strip topsoil from easement and reinstatement shall state any limitations on the width to be stripped and reinstated.</p> <p>A10 Item descriptions for reinstatement of land and for strip topsoil from easement and reinstatement shall distinguish between grassland, gardens, sports fields and cultivated land.</p>
<p>M9 Other pipework ancillaries shall be measured for pipes, ducts and metal culverts.</p> <p>M10 The lengths measured for reinstatement of field drains shall be the nominal trench width defined in accordance with rule D1 in class L.</p> <p>M11 The area measured for supports left in excavations shall be the undeveloped area in contact with the surfaces for which the supports are expressly required to be left in</p>	<p>D7 The dimension used for classification of bore in the third division shall be the maximum nominal distance between the inside faces of the outer walls of the pipe, duct or culvert to be installed.</p>	<p>C10 Items for reinstatement of field drains shall be deemed to include connections to existing field drains.</p>	<p>A11 Sizes and types of marker posts shall be stated in item descriptions.</p> <p>A12 Item descriptions for connections to existing manholes and other chambers and to existing pipes, ducts and culverts shall identify the nature of the existing service and the extent of the work to be included.</p>

CLASS L: PIPEWORK — SUPPORTS AND PROTECTION, ANCILLARIES TO LAYING AND EXCAVATION

- Includes:** Extras to excavation and backfilling of trenches for pipework, ducts and metal culverts, manholes and other chambers, headings, thrust boring and pipe jacking
 Pipe laying in headings and by thrust boring and pipe jacking
 Provision of supports and protection to pipework, ducts and metal culverts
- Excludes:** Work included in classes I, J, K and Y
 Insulation to building services (included in class Z)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Extras to excavation and backfilling m ³	1 In pipe trenches 2 In manholes and other chambers 3 In headings 4 In thrust boring 5 In pipe jacking	1 Excavation of rock 2 Excavation of mass concrete 3 Excavation of reinforced concrete 4 Excavation of other artificial hard material 5 Backfilling above the Final Surface with concrete 6 Backfilling above the Final Surface with stated material other than concrete 7 Excavation of natural material below the Final Surface and backfilling with concrete 8 Excavation of natural material below the Final Surface and backfilling with stated material other than concrete

CLASS L

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Items shall be given in this class in addition to the items for provision, laying and jointing of pipes, ducts and culverts and for the excavation and backfilling of trenches in classes I and K. Items shall be given in this class in addition to the items for manholes and other chambers in classes K and Y.</p> <p>M2 Work in this class associated with ducts and metal culverts shall be measured as set out for work associated with pipes. The dimension used for classification in the third division (L 2-8 + 4) shall be the maximum nominal distance between the inside faces of the outer duct or culvert walls.</p> <p>M3 Dressing up and reinstatement of roads and pavings shall be included in class K.</p>		<p>C1 Items for work in this class shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling and removal of dead services, except to the extent that such work is included in classes I, J and K or in the items for extras to excavation and backfilling in this class.</p> <p>C2 Items for work in this class shall be deemed to include concrete, reinforcement, formwork, joints and finishes.</p>	
<p>M4 The volume of extras to excavation and backfilling in pipe trenches shall be calculated by multiplying together the average depth and length of the material removed or backfilled and the nominal trench width.</p> <p>M5 No volume of extras to excavation and backfilling in manholes and other chambers shall be measured outside the maximum plan area of the manhole or other chamber.</p> <p>M6 The volume of extras to excavation and backfilling for pipe laying in headings, in thrust boring and in pipe jacking shall be measured by multiplying together the internal cross-sectional area of pipe and the length of the material excavated or backfilled. Packing in headings shall not be measured.</p> <p>M7 Backfilling above the Final Surface (L 1 + 5-6) shall be measured only where it is expressly required that the material excavated shall not be used for backfilling. Excavation below the Final Surface and backfilling (L 1 + 7-8) shall be measured only where it is expressly required.</p> <p>M8 An isolated volume of rock, concrete or other artificial hard material occurring within other material to be excavated shall not be measured separately unless its volume exceeds 0.25 m³.</p>	<p>D1 The nominal trench width if not stated in the Contract shall be taken as 600 mm greater than the maximum nominal distance between the inside faces of the outer pipe walls where this distance does not exceed 1 m and as 750 mm greater than this distance where it exceeds 1 m.</p>		<p>A1 Item descriptions shall identify separately excavation which is expressly required to be carried out by hand.</p>

CLASS L

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
2 Special pipe laying methods	m 1 In headings 2 Thrust boring 3 Pipe jacking	1 Nominal bore: not exceeding 200 mm 2 200–300 mm 3 300–500 mm 4 500–900 mm 5 900–1 200 mm 6 1 200–1 500 mm 7 1 500–1 800 mm 8 stated exceeding 1 800 mm
3 Beds	m 1 Sand	
4 Haunches	m 2 Selected excavated granular material	
5 Surrounds	m 3 Imported granular material 4 Mass concrete 5 Reinforced concrete	
6 Wrapping and lagging	m	
7 Concrete stools and thrust blocks	nr 1 Volume: not exceeding 0.1 m ³ 2 0.1–0.2 m ³ 3 0.2–0.5 m ³ 4 0.5–1 m ³ 5 1–2 m ³ 6 2–4 m ³ 7 4–5 m ³ 8 stated exceeding 5 m ³	
8 Other isolated pipe supports	nr 1 Height: not exceeding 1 m 2 1–1.5 m 3 1.5–2 m 4 2–3 m 5 3–4 m 6 4–5 m 7 5–6 m 8 stated exceeding 6 m	

CLASS L

(see rules at head of class on page 57)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M9 <i>Special pipe laying methods</i> shall be measured only where they are expressly required.</p> <p>M10 Access pits, shafts and jacking blocks, where expressly stated in the Contract to be executed by the Contractor and of which the nature and extent are expressly stated in the Contract, shall be measured as Specified Requirements in class A.</p>		<p>C3 Items for <i>special pipe laying methods</i> shall be deemed to include crossings, provision and removal of access pits, shafts and jacking blocks unless otherwise stated and other work associated with special pipe laying methods not included in the items for provision, laying and jointing of pipes given in class L.</p>	<p>A2 Item descriptions for <i>special pipe laying methods</i> shall identify the run of pipe or pipes. The type of packing shall be stated in item descriptions for pipes in headings.</p>
<p>M11 Lengths of <i>beds, haunches and surrounds</i> shall be measured along pipe centre lines including lengths occupied by fittings and valves but not including lengths occupied by manholes and other chambers through which they are not continued.</p>	<p>D2 Items for <i>haunches and surrounds</i> shall include <i>beds</i> of the same material.</p> <p>D3 Items for <i>beds, haunches and surrounds</i> to multiple pipes shall be classified in the third division according to the nominal distance between the inside faces of the outer pipe walls.</p>		<p>A3 Materials used for <i>beds, haunches and surrounds</i> and the depths of <i>beds</i> shall be stated in item descriptions.</p> <p>A4 <i>Beds, haunches and surrounds</i> to multiple pipes shall be so described stating the number of pipes and the maximum nominal distance between the inside faces of the outer pipe walls.</p>
<p>M12 Lengths of <i>wrapping and lagging</i> shall be measured along each pipe centre line including lengths occupied by fittings and valves but not including lengths occupied by manholes and other chambers through which the pipes are not continued.</p>		<p>C4 Items for <i>wrapping and lagging of pipes</i> shall be deemed to include wrapping and lagging of fittings, valves and joints.</p>	<p>A5 Materials used for <i>wrapping and lagging</i> of pipes shall be stated in item descriptions.</p>
	<p>D4 The volumes used for classification of <i>concrete stools and thrust blocks</i> shall exclude the volumes occupied by pipes.</p>	<p>C5 Items for <i>concrete stools and thrust blocks</i> shall be deemed to include pipe fixings.</p>	<p>A6 Item descriptions for <i>concrete stools and thrust blocks</i> shall state the specification of the concrete and whether it is reinforced.</p>
	<p>D5 The height of <i>pipe supports</i> used for classification shall be measured from the ground or other supporting surface to the invert of the highest pipe where pipes are supported from below and of the lowest pipe where pipes are supported from above.</p> <p>D6 Where two or more pipes are carried by one support, the item for the support shall be classified in the third division by the aggregate bore of the pipes supported.</p>		<p>A7 Principal dimensions and materials shall be stated in item descriptions for <i>pipe supports</i>.</p>

CLASS M: STRUCTURAL METALWORK

Excludes: Metalwork in concrete (included in classes C, G and H)
 Metalwork in pipework (included in classes I, J, K and L)
 Miscellaneous metalwork (included in class N)
 Metalwork in piles (included in classes P and Q)
 Metalwork in fences (included in class X)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Fabrication of main members for bridges t	1 Rolled sections 2 Plates or flats 3 Built-up box or hollow sections	1 Straight on plan 2 Curved on plan 3 Straight on plan and cambered 4 Curved on plan and cambered
2 Fabrication of subsidiary members for bridges t	1 Deck panels 2 Bracings 3 External diaphragms	
3 Fabrication of members for frames 4 Fabrication of other members	1 Columns t 2 Beams t 3 Portal frames t 4 Trestles, towers and built-up columns t 5 Trusses and built-up girders t 6 Bracings, purfins and cladding rails t 7 Girders t 8 Anchorages and holding down bolt assemblies nr	1 Straight on plan 2 Curved on plan 3 Straight on plan and cambered 4 Curved on plan and cambered
5 Erection of members for bridges 6 Erection of members for frames 7 Erection of other members	1 Trial erection t 2 Permanent erection t 3 Site bolts: black nr 4 HSPG general grade nr 5 HSPG higher grade nr 6 HSPG load indicating or load limit types, general grade nr 7 HSPG load indicating or load limit types, higher grade nr	1 Diameter: not exceeding 16 mm 2 16-20 mm 3 20-24 mm 4 24-30 mm 5 30-36 mm 6 36-42 mm 7 stated exceeding 42 mm
8 Off site surface treatment m ²	1 Blast cleaning 2 Pickling 3 Flame cleaning 4 Wire brushing 5 Metal spraying 6 Galvanizing 7 Painting	

CLASS M

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Items shall be included in miscellaneous metalwork (class N) for metal components not included in this class but associated with metal structures.</p>			
<p>M2 The mass of members, other than plates or flats, shall be calculated from the overall lengths of the members with no deductions for splay-out or mitred ends.</p> <p>M3 The mass of members measured shall be that of plates, rolled sections, shear connectors, stiffeners, cleats, packs, splice plates and other fittings.</p> <p>M4 No allowance shall be made in the measurements for rolling margin and other permissible deviations. The mass of weld fillets, bolts, nuts, washers, rivets and protective coatings shall not be measured.</p> <p>M5 No deductions shall be made for the mass of metal removed to form notches and holes each not exceeding 0.1 m² in area measured in plane.</p> <p>M6 The mass of steel to BS 4380 shall be taken for measurement as 785 kg/m² per 100 mm thickness (7.85 t/m³). The masses of other metals shall be taken as stated in the Specification or, where not so stated, as stated in the supplier's catalogue.</p> <p>M7 Anchorages and holding down bolt assemblies shall be measured by the number of complete assemblies.</p>		<p>C1 Items for fabrication of metalwork shall be deemed to include delivery of fabricated metalwork to the Site.</p>	<p>A1 The materials and grades of materials used shall be stated in item descriptions for fabrication of members.</p> <p>A2 Item descriptions for fabrication of members shall identify tapered or castellated members.</p> <p>A3 Item descriptions for fabrication of members other than for portal frames shall identify cranked members.</p> <p>A4 Details of the members comprising room and infill construction shall be stated in item descriptions for trusses, towers and built-up columns and trusses and built-up girders.</p> <p>A5 Item descriptions for anchorages and holding down bolt assemblies shall state particulars of the type of anchorage or assembly.</p>
		<p>C2 Items for erection of members shall be deemed to include work carried out after delivery of fabricated metalwork to the Site.</p> <p>C3 Items for site bolts shall be deemed to include supply and delivery to the Site.</p>	<p>A6 Item descriptions for erection shall separately identify and locate separate bridges and structural frames and, where appropriate, parts of bridges or frames.</p> <p>A7 Where fixing clips and resilient pads are used to secure overhead crane rails, item descriptions shall so state.</p>
<p>M8 Surface treatment carried out on the Site shall be classed as painting (class V).</p>			<p>A8 Materials and number of applications shall be stated in item descriptions for metal spraying, galvanizing and painting.</p>

CLASS N: MISCELLANEOUS METALWORK

Excludes: Metal reinforcement for concrete (included in classes C, G, H and R)
 Metal inserts in concrete (included in classes G and H)
 Pipework (included in classes I, J, K and L)
 Structural metalwork (included in class M)
 Fittings and fastenings to timber (included in class O)
 Piles (included in classes P and Q)
 Traffic signs (included in class R)
 Rail track and accessories (included in class S)
 Fences (included in class X)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION	
1	1 Stairways and landings	t	
	2 Walkways and platforms	t	
	3 Ladders	m	
	4 Handrails	m	
	5 Bridge parapets	m	
	6 Miscellaneous framing	m	1 Angle section 2 Channel section 3 I section 4 Tubular section
	7 Plate flooring	m ²	
	8 Open grid flooring	m ²	
	2	1 Cladding	m ²
		2 Welded mesh panelling	m ²
3 Duct covers		m ²	
4 Tie rods		nr	
5 Walings		m	
6 Bridge bearings		nr	1 Roller 2 Slide 3 Rocker 4 Cylindrical 5 Spherical 6 Plain rubber 7 Laminated rubber 8 Rubber pot
7 Uncovered tanks		nr	1 Volume: not exceeding 1 m ³
8 Covered tanks		nr	2 1-3 m ³ 3 3-10 m ³ 4 10-30 m ³ 5 30-100 m ³ 6 100-300 m ³ 7 300-1000 m ³ 8 stated exceeding 1000 m ³

CLASS O: TIMBER

Includes: Timber components and fittings
Timber decking

Fittings and fastenings to timber components and decking

Excludes: Formwork to concrete (included in class G)

Timber piles (included in class P)

Timber sleepers (included in class S)

Timber supports in tunnels (included in class T)

Timber fencing (included in class X)

Carpentry and joinery in simple building works incidental to civil engineering works (included in class Z)

FIRST DIVISION		SECOND DIVISION		THIRD DIVISION		
1	Hardwood components	m	1	Cross-sectional area: not exceeding 0.01 m ²	1	Length: not exceeding 1.5 m
2	Softwood components	m	2	0.01-0.02 m ²	2	1.5-3 m
			3	0.02-0.04 m ²	3	3-5 m
			4	0.04-0.1 m ²	4	5-8 m
			5	0.1-0.2 m ²	5	8-12 m
			6	0.2-0.4 m ²	6	12-20 m
			7	exceeding 0.4 m ²	7	stated exceeding 20 m
3	Hardwood decking	m ²	1	Thickness: not exceeding 25 mm		
4	Softwood decking	m ²	2	25-50 mm		
			3	50-75 mm		
			4	75-100 mm		
			5	100-125 mm		
			6	125-150 mm		
			7	exceeding 150 mm		
5	Fittings and fastenings	nr	1	Straps		
			2	Spikes		
			3	Coach screws		
			4	Bolts		
			5	Plates		

CLASS O

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
		<p>C1 Items for timber shall be deemed to include fixing, boring, cutting and jointing.</p>	
<p>M1 The length of timber components measured shall be their overall lengths with no allowance for scarfed or other joints.</p>	<p>D1 The cross-sectional areas stated for classification of timber components shall be their nominal gross cross-sectional areas.</p>		<p>A1 The nominal gross cross-sectional dimensions, thicknesses, grade or species and any impregnation requirements or special surface finishes shall be stated in item descriptions for timber components.</p> <p>A2 The structural use and location of timber components shall be stated in item descriptions for components longer than 3 m.</p>
<p>M2 No deduction from the areas measured for timber decking shall be made for openings and holes each not exceeding 0.5 m² in area.</p>	<p>D2 The thickness stated for classification of timber decking shall be the nominal gross thickness.</p>		<p>A3 The nominal gross cross-sectional dimensions, thicknesses, species and any impregnation requirements or special surface finishes shall be stated in item descriptions for timber decking.</p>
			<p>A4 Materials, types and sizes of fittings and fastenings shall be stated in item descriptions.</p>

CLASS P: PILES

Excludes: Boring for site investigation (included in class B)
 Ground anchors (included in class C)
 Walings and tie rods (included in class N)
 Piling ancillaries (included in class Q)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Bored cast in place concrete piles 2 Driven cast in place concrete piles	1 Diameter: 300 mm or 350 mm 2 400 mm or 450 mm 3 500 mm or 550 mm 4 600 mm or 750 mm 5 900 mm or 1050 mm 6 1200 mm or 1350 mm 7 1500 mm	1 Number of piles 2 Concrete length 3 Depth bored or driven to stated maximum depth
3 Preformed concrete piles 4 Preformed prestressed concrete piles 5 Preformed concrete sheet piles 6 Timber piles	1 Cross-sectional area: not exceeding 2 0.025-0.06 m ² 3 0.06-0.1 m ² 4 0.1-0.15 m ² 5 0.15-0.25 m ² 6 0.25-0.5 m ² 7 0.5-1 m ² 8 exceeding 1 m ²	1 Number of piles of stated length 2 Depth driven
7 Isolated steel piles	1 Mass: not exceeding 15 kg/m 2 15-30 kg/m 3 30-60 kg/m 4 60-120 kg/m 5 120-250 kg/m 6 250-500 kg/m 7 500 kg/m-1 t/m 8 exceeding 1 t/m	1 Number of piles of stated length 2 Depth driven

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Bored and driven depths shall be measured along the axes of piles from the Commencing Surface to the toe levels of bored piles, to the bottom of the casings of driven cast in place piles and to the bottom of the toes of other driven piles. The Commencing Surface adopted in the preparation of the Bill of Quantities as the surface at which boring or driving is expected to begin shall be adopted for the measurement of the completed work.</p>		<p>C1 Items for piles shall be deemed to include disposal of excavated material.</p>	<p>A1 Materials of which piles are composed shall be stated in item descriptions.</p> <p>A2 Preliminary piles shall be identified in item descriptions. Raked piles shall be identified in item descriptions and their inclination ratios stated.</p> <p>A3 The structure to be supported and the Commencing Surface shall be identified in item descriptions for piles.</p>
<p>M2 Each group of items for <i>cast in place concrete piles</i> shall comprise</p> <p>(a) an item for the <i>number of piles</i> (P 1-2 + 1)</p> <p>(b) an item for the <i>total concreted length of piles</i> (P 1-2 + 2)</p> <p>(c) an item for the <i>total depth bored or driven</i> (P 1-2 + 3).</p> <p>M3 The <i>concreted lengths of cast in place concrete piles</i> shall be measured from the cut off levels expressly required to the toe levels expressly required.</p>	<p>D1 The maximum depth stated in item descriptions for the depth of <i>cast in place concrete piles</i> shall be the depth which is not exceeded by any pile included in the item.</p> <p>D2 Piles comprising a driven permanent steel casing which is filled with concrete shall be classed as <i>driven cast in place concrete piles</i> where the piles are designed for the load to be carried on the concrete.</p>		<p>A4 The diameter shall be stated in item descriptions for <i>cast in place concrete piles</i>.</p> <p>A5 Contiguous bored piles shall be identified in item descriptions.</p>
<p>M4 Each group of items for <i>preformed concrete and timber piles</i> shall comprise</p> <p>(a) one or more items for the <i>number of piles of stated length</i> (P 3-6 + 1)</p> <p>(b) an item for the <i>total depth driven</i> (P 3-6 + 2).</p>	<p>D3 The lengths of <i>preformed concrete and timber piles</i> shall be the lengths expressly required to be supplied excluding extensions but including heads and shoes.</p>		<p>A6 The cross-section type and cross-sectional dimensions or diameter shall be stated in item descriptions for <i>preformed concrete and timber piles</i>.</p> <p>A7 Details of treatments and coatings shall be stated in item descriptions for the <i>number of piles</i>.</p> <p>A8 Details of driving heads and shoes shall be stated in item descriptions for the <i>number of piles</i>.</p>
<p>M5 Each group of items for <i>isolated steel piles</i> shall comprise</p> <p>(a) one or more items for the <i>number of piles of stated length</i> (P 7 + 1)</p> <p>(b) an item for the <i>total depth driven</i> (P 7 + 2).</p>	<p>D4 The lengths of <i>isolated steel piles</i> shall be the lengths expressly required to be supplied excluding extensions.</p> <p>D5 Piles comprising a driven permanent steel casing which is filled with concrete shall be classed as <i>isolated steel piles</i> where the piles are designed for the load to be carried on the casing. Filling such piles shall be classed as <i>filling hollow piles with concrete</i> (Q 53 + 1).</p>		<p>A9 The mass per metre and cross-sectional dimensions shall be stated in item descriptions for <i>isolated steel piles</i>.</p> <p>A7 Details of treatments and coatings shall be stated in item descriptions for the <i>number of piles</i>.</p>

CLASS P

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
8 Inter-locking steel piles	<ol style="list-style-type: none"> 1 Section modulus: not exceeding 500 cm³/m 2 500-800 cm³/m 3 800-1200 cm³/m 4 1200-2000 cm³/m 5 2000-3000 cm³/m 6 3000-4000 cm³/m 7 4000-5000 cm³/m 8 exceeding 5000 cm³/m. 	<ol style="list-style-type: none"> 1 Length of special piles m 2 Driven area m² 3 Area of piles of length: <ol style="list-style-type: none"> not exceeding 14 m m² 14-24 m m² exceeding 24 m m²

CLASS P

[see rules at head of class on page 67]

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M6 Each group of items for <i>interlocking steel piles</i> shall comprise</p> <p>(a) one or more items for the total length of each type of <i>special pile</i>, if any (P 8 + 1)</p> <p>(b) an item for the total <i>driven area</i> of piles (P 8 + 2)</p> <p>(c) one or more items for the total <i>area of piles</i> divided into the ranges of length given in the third division (P 8 + 3-5).</p> <p>M7 The areas of <i>interlocking steel piles</i> shall be calculated by multiplying the mean undeveloped horizontal lengths of the pile walls formed (including lengths occupied by special piles) by the depths measured in accordance with rule M1 in the case of items for the driven areas (P 8 + 2) and by the lengths defined in accordance with rule D6 in the case of items for the areas of piles (P 8 + 3-5).</p> <p>M8 Closure and taper piles classed as <i>special piles</i> shall be measured only where they are expressly required.</p>	<p>D6 The lengths of <i>interlocking steel piles</i> shall be the lengths expressly required to be supplied excluding extensions.</p> <p>D7 Interlocking steel corner, junction, closure and taper piles shall be classed as <i>special piles</i>.</p>		<p>A10 The section reference or mass per metre and section modulus shall be stated in item descriptions for <i>interlocking steel piles</i>.</p> <p>A11 Details of treatments and coatings shall be stated in item descriptions for <i>area of piles</i>.</p> <p>A12 The type of special pile shall be stated in item descriptions for the length of <i>special piles</i>.</p>

CLASS Q

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Work in this class, other than <i>backfilling empty bore</i> for cast in place concrete piles, shall be measured only where it is expressly required.</p>		<p>C1 Items for piling ancillaries shall be deemed to include disposal of surplus materials unless otherwise stated.</p>	
<p>M2 The lengths of <i>permanent casings</i> shall be measured from the Commencing Surface to the bottom of the casing.</p>	<p>D1 The <i>diameter</i> used for classification in the third division shall be the diameter of the piles.</p>	<p>C2 Items for <i>permanent casings</i> shall be deemed to include driving heads and shoes.</p>	<p>A1 The diameters of <i>enlarged bases</i> for cored piles shall be stated in item descriptions.</p> <p>A2 Materials, thickness and details of treatments and coatings shall be stated in item descriptions for <i>permanent casings</i>. Item descriptions for <i>cutting off surplus lengths</i> which include permanent casings shall so state.</p>
<p>M3 The mass measured for reinforcement shall include the mass of reinforcement in <i>bous</i>.</p> <p>M4 The mass of steel reinforcement shall be taken as 0.785 kg/m per 100 mm² of cross-section (7.85 t/m³). The mass of other reinforcing materials shall be taken as stated in the Contract.</p>	<p>D2 The nominal size used for classification in item descriptions for <i>bar reinforcement</i> shall be the cross-sectional size defined in BS 4449.</p>	<p>C3 Items for <i>reinforcement</i> shall be deemed to include supporting reinforcement.</p>	<p>A3 Materials shall be stated in item descriptions for <i>reinforcement</i>.</p> <p>A4 Details of couplers for high tensile steel reinforcement which are expressly required shall be stated in item descriptions for <i>reinforcement</i>.</p>
<p>M5 Driving extended piles shall be included in the measurement of the items for driven depth in class P.</p> <p>M6 Each group of items for <i>pile extensions</i> shall comprise</p> <p>(a) an item for the number of <i>pile extensions</i> (Q 3-4 4 +);</p> <p>(b) one or two items for the length of <i>pile extensions</i> divided into the ranges of length given in the second division (Q 3-4 5-6 +).</p> <p>M7 The length of <i>pile extensions</i> measured shall not include lengths formed from material arising from cutting off surplus lengths of other piles.</p> <p>M8 The length measured for <i>smaller pile extensions</i> shall include lengths occupied by scarfed or other joints.</p>	<p>D3 The <i>cross-sectional area</i> used for classification in the third division shall be the cross-sectional area of the piles.</p>	<p>C4 Items for <i>pre-boring</i> shall be deemed to include grouting voids between the pile and the bore.</p> <p>C5 Items for <i>pile extensions</i> shall be deemed to include the work necessary to attach the extension to the pile.</p> <p>C6 Items for <i>filling hollow piles with concrete</i> shall be deemed to include removal of material from within the pile before concreting.</p>	<p>A5 Item descriptions for <i>filling hollow piles with concrete</i> shall state the specification of the concrete.</p> <p>A6 Materials of which <i>pile extensions</i> are composed shall be stated in item descriptions for their length.</p>
<p>M5 Driving extended piles shall be included in the measurement of the items for driven depth in class P.</p> <p>M6 Each group of items for <i>pile extensions</i> shall comprise</p> <p>a) an item for the number of <i>pile extensions</i> (Q 5 4 +);</p> <p>b) one or two items for the length of <i>pile extensions</i> divided into the ranges of length given in the second division (Q 5 5-6 +).</p> <p>M7 The length of <i>pile extensions</i> measured shall not include lengths formed from material arising from cutting off surplus lengths of other piles.</p>	<p>D4 The mass used for classification in the third division shall be the mass of the piles.</p>	<p>C4 Items for <i>pre-boring</i> shall be deemed to include grouting voids between the pile and the bore.</p> <p>C5 Items for <i>pile extensions</i> shall be deemed to include the work necessary to attach the extension to the pile.</p> <p>C6 Items for <i>filling hollow piles with concrete</i> shall be deemed to include removal of material from within the pile before concreting.</p>	<p>A5 Item descriptions for <i>filling hollow piles with concrete</i> shall state the specification of the concrete.</p> <p>A6 Materials of which <i>pile extensions</i> are composed shall be stated in item descriptions for their length.</p>

CLASS Q

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
6 Interlocking steel piles	1 Pre-boring m 2 Jetting m 4 Number of pile extensions nr 5 Length of pile extensions, each length: not exceeding 3 m m exceeding 3 m m 7 Cutting off surplus lengths m 8 Preparing heads nr	1 Section modulus: not exceeding 500 cm ³ /m 2 500-800 cm ³ /m 3 800-1200 cm ³ /m 4 1200-2000 cm ³ /m 5 2000-3000 cm ³ /m 6 3000-4000 cm ³ /m 7 4000-5000 cm ³ /m 8 stated exceeding 5000 cm ³ /m
7 Obstructions	h	
8 Pile tests	nr	1 Test load: not exceeding 100 t 2 100-200 t 3 200-300 t 4 300-400 t 5 400-600 t 6 600-800 t 7 800-1000 t 8 exceeding 1000 t
		4 Non-destructive integrity 5 Inclinator installations

CLASS Q

(see rules at head of class on page 71)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M5 Driving extended piles shall be included in the measurement of the items for driven depth in class P.</p> <p>M10 Each group of items for <i>pile extensions</i> shall comprise</p> <p>(a) an item for the <i>number of pile extensions</i> (Q 6 4 +)</p> <p>(b) one or two items for the <i>length of pile extensions</i> divided into the ranges of length given in the second division (Q 6 5-6 +).</p> <p>M7 The length of <i>pile extensions</i> measured shall not include lengths formed from material arising from cutting off surplus lengths of other piles.</p> <p>M11 The lengths measured for <i>cutting off surplus lengths of interlocking steel piles</i> shall be the mean undeveloped horizontal lengths to be cut (including lengths occupied by special piles).</p>	<p>D5 The <i>section modulus</i> used for classification in the third division shall be the section modulus of the piles.</p>	<p>C5 Items for <i>pile extensions</i> shall be deemed to include the work necessary to attach the extension to the pile.</p>	<p>A6 Materials of which <i>pile extensions</i> are composed shall be stated in item descriptions for their length.</p>
<p>M12 <i>Obstructions</i> shall be measured only for breaking out rock or artificial hard material encountered above the founding stratum of bored piles.</p>			
			<p>A7 Item descriptions for <i>pile tests</i> shall identify those which are to preliminary piles.</p> <p>A8 Item descriptions for loading tests shall state the load. Where the load is applied to raking piles item descriptions shall so state.</p>

CLASS R: ROADS AND PAVINGS

- Includes:** Sub-base, base and surfacing of roads, runways and other paved areas
Kerbing and light duty pavements, footways and cycle tracks
Traffic signs and markings
- Excludes:** Earthworks (included in class E)
Drainage (included in classes I, J, K and L)
Fences and gates (included in class X)
Gantries and other substantial structures supporting traffic signs
Maintenance of roads and pavings

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Sub-bases, flexible road bases and surfacing	1 Granular material DTp Specified type 1 m ²	1 Depth: not exceeding 30 mm
	2 Granular material DTp Specified type 2 m ²	2 30-60 mm
	3 Soil cement m ²	3 60-100 mm
	4 Cement-bound granular material m ²	4 100-150 mm
	5 Lean concrete DTp Specified strength m ²	5 150-200 mm
	6 Hardcore m ²	6 200-250 mm
		7 250-300 mm
		8 exceeding 300 mm
2 Sub-bases, flexible road bases and surfacing	7 Geotextiles m ²	
	8 Additional depth of stated material m ³	
	1 Wet mix macadam m ²	1 Depth: not exceeding 30 mm
	2 Dry bound macadam m ²	2 30-60 mm
	3 Dense bitumen macadam m ²	3 60-100 mm
	4 Open texture bitumen macadam m ²	4 100-150 mm
	5 Dense tarmacadam m ²	5 150-200 mm
	6 Open texture tarmacadam m ²	6 200-250 mm
7 Dense tar surfacing m ²	7 250-300 mm	
3 Sub-bases, flexible road bases and surfacing		8 exceeding 300 mm
	1 Cold asphalt wearing course m ²	
	2 Rolled asphalt m ²	
	3 Slurry sealing m ²	
	4 Surface dressing m ²	
	5 Bituminous spray m ²	
	6 Removal of flexible surface m ²	
	8 Regulating course of stated material t	
4 Concrete pavements	1 Carriageway slabs of DTp Specified paving quality concrete m ²	1 Depth: not exceeding 30 mm
	2 Other carriageway slabs of stated strength m ²	2 30-60 mm
	3 Other in situ concrete slabs of stated strength m ²	3 60-100 mm
		4 100-150 mm
		5 150-200 mm
		6 200-250 mm
		7 250-300 mm
		8 exceeding 300 mm
	4 Steel fabric reinforcement to BS 4483 m ²	1 Nominal mass: not exceeding 2 kg/m ²
	5 Other fabric reinforcement of stated material m ²	2 2-3 kg/m ²
		3 3-4 kg/m ²
		4 4-5 kg/m ²
		5 5-6 kg/m ²
		6 6-7 kg/m ²
		7 7-8 kg/m ²
		8 stated exceeding 8 kg/m ²
6 Plain round steel bar reinforcement to BS 4449 t	1 Nominal size: 6 mm	
7 Deformed high yield steel bar reinforcement to BS 4449 t	2 8 mm	
	3 10 mm	
	4 12 mm	
	5 16 mm	
	6 20 mm	
	7 25 mm	
	8 32 mm or greater	
8 Waterproof membranes below concrete pavements m ²		

CLASS R

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The width of each course of materials shall be measured at the top surface of that course. The areas of manhole covers and other intrusions into a course shall not be deducted where the area of the intrusion is less than 1 m².</p> <p>M2 The area of additional geotextiles in laps shall not be measured.</p>	<p>D1 The expression 'DTa Specified' shall mean as specified in the Specification for road and bridge works issued by the Department of Transport.</p>	<p>C1 Items for work in this class involving in situ concrete shall be deemed to include formwork and finishes to concrete.</p>	<p>A1 Item descriptions for all courses of paving, road making materials and pavement slabs shall identify the material and state the depth of each course or slab and the spread rate of applied surface finishes.</p> <p>A2 Item descriptions for work in this class which is applied to surfaces inclined at an angle exceeding 10° to the horizontal shall so state.</p>
<p>M3 The areas of additional fabric reinforcement in laps shall not be measured.</p>	<p>D2 The nominal size stated in item descriptions for bar reinforcement shall be the cross-sectional size defined in BS 4449.</p>	<p>C2 Items for reinforcement shall be deemed to include supporting reinforcement other than steel supports to top reinforcement.</p>	<p>A3 The type and grade of material shall be stated in item descriptions for geotextiles.</p>
<p>M4 The mass of steel reinforcement shall be taken as 0.785 kg/m per 100 mm² of cross-section (7.85 N/m²). The mass of other reinforcing materials shall be taken as stated in the Contract.</p> <p>M5 The mass of reinforcement measured shall include the mass of steel supports to top reinforcement.</p>	<p>D2 The nominal size stated in item descriptions for bar reinforcement shall be the cross-sectional size defined in BS 4449.</p>	<p>C2 Items for reinforcement shall be deemed to include supporting reinforcement other than steel supports to top reinforcement.</p>	<p>A4 Item descriptions for steel fabric reinforcement to BS 4483 shall state the fabric reference in accordance with BS 4483 or the wire and mesh arrangement in accordance with BS 4466. Item descriptions for other fabric reinforcement shall state the sizes and nominal mass per square metre.</p>
<p>M6 The areas of additional waterproof membranes in laps shall not be measured.</p>	<p>D2 The nominal size stated in item descriptions for bar reinforcement shall be the cross-sectional size defined in BS 4449.</p>	<p>C2 Items for reinforcement shall be deemed to include supporting reinforcement other than steel supports to top reinforcement.</p>	<p>A5 Item descriptions for waterproof membranes shall state their materials and</p>

CLASS R

FIRST DIVISION		SECOND DIVISION	THIRD DIVISION
5 Joints in concrete pavements	m	1 Longitudinal joints 2 Expansion joints 3 Contraction joints 4 Warping joints 5 Butt joints 6 Construction joints	1 Depth of joint: not exceeding 30 mm 2 30-60 mm 3 60-100 mm 4 100-150 mm 5 150-200 mm 6 200-250 mm 7 250-300 mm 8 exceeding 300 mm
6 Kerbs, channels and edgings		1 Precast concrete kerbs to BS 7263: Part 1 figure 1(b), (c) and (d) 2 Precast concrete kerbs to BS 7263: Part 1 figure 1(a) and (e) 3 Precast concrete channels to BS 7263: Part 1 figure 1(f) and (g) 4 Precast concrete channels to BS 7263: Part 1 figure 1(h) 5 Precast concrete edgings to BS 7263: Part 1 figure 1(m), (n) and (p) 6 In situ concrete kerbs and edgings 7 Asphalt kerbs 8 Asphalt channels	1 Straight or curved to radius exceeding 12 m m 2 Curved to radius not exceeding 12 m m 3 Quadrants nr 4 Drops nr 5 Transitions nr
7 Light duty pavements	m ²	1 Granular base 2 Hardcore base 3 Tarmacadam 4 Rolled asphalt 5 Bitumen macadam 6 Dense tar 7 In situ concrete of stated strength 8 Precast concrete flags to stated specification	1 Depth: not exceeding 30 mm 2 30-60 mm 3 60-100 mm 4 100-150 mm 5 150-200 mm 6 200-250 mm 7 250-300 mm 8 exceeding 300 mm
8 Ancillaries		1 Traffic signs	1 Non-illuminated nr 2 Illuminated nr
		2 Surface markings	1 Non-reflecting road studs nr 2 Reflecting road studs nr 3 Letters and shapes nr 4 Continuous lines m 5 Intermittent lines m

CLASS R

(see rules at head of class on page 75)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
M7 <i>Construction joints</i> shall be measured only where they are at locations where construction joints are expressly required.			A6 The dimensions, sodding and nature of sealed grooves and rebates, waterstops, dowels and other components shall be stated in item descriptions for <i>joints in concrete pavements</i> .
M8 Excavation and filling for <i>kerbs, channels and edgings</i> shall be classed as earthworks (class E).		C3 Items for <i>kerbs, channels and edgings</i> shall be deemed to include beds, backings, reinforcement, joints and cutting.	A7 Materials and cross-sectional dimensions of <i>kerbs, channels and edgings</i> and their beds and backings shall be stated in item descriptions.
M1 The width of each course of materials shall be measured at the top surface of that course. The areas of manhole covers and other intrusions into a course shall not be deducted where the area of the intrusion is less than 1 m ² .			
M9 Lengths measured for linear <i>surface markings</i> shall exclude gaps in intermittent markings. M10 Items for support gantries and other substantial structures associated with <i>traffic signs</i> which are constructed in concrete, structural metalwork or other materials shall be given in the appropriate classes.		C4 Items for <i>traffic signs</i> other than traffic signs measured in accordance with rule M10 shall be deemed to include foundations, supporting posts, excavation, preparation of surfaces, disposal of excavated material, removal of existing services, upholding sides of excavation, backfilling, concrete, reinforcement and joints.	A8 The material, size and diagram number taken from <i>Traffic signs, regulations and general directions</i> , issued by the Department of Transport, shall be stated in item descriptions for <i>traffic signs and surface markings</i> . A9 The shape and colour of aspects shall be stated in item descriptions for <i>reflecting road studs</i> .

NOTE

Earthworks for *kerbs, channels and edgings* may be included in the items in this class provided that the work included is identified in the item descriptions and that appropriate statements are given in the Preamble in accordance with paragraph 5.4.

CLASS S: RAIL TRACK

Includes: Track foundations, rails, sleepers, fittings, switches and crossings

Excludes: Overhead crane rails (included in class M)
Concrete track foundations (included in classes F and G)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Track foundations	1 Bottom ballast m ³ 2 Top ballast m ³ 3 Blinding m ² 4 Blankets m ² 5 Waterproof membranes m ²	
2 Taking up	1 Bullhead rails 2 Flat bottom rails 3 Dock and crane rails 4 Check and guard rails m 5 Conductor rails m 8 Sundries nr	1 Plain track 4 Turnouts 5 Diamond crossings 1 Buffer stops 2 Retarders 3 Wheel stops 4 Lubricators 5 Switch heaters 6 Switch levers
3 Lifting, packing and slewing nr	1 Bullhead rail track 2 Bullhead rail track with turnout 3 Flat bottom rail track 4 Flat bottom rail track with turnout 5 Buffer stops	
4 Supplying	1 Bullhead rails t 2 Flat bottom rails t 3 Dock and crane rails t 4 Check and guard rails t 5 Conductor rails t 6 Twist rails nr 7 Sleepers nr 8 Fittings nr	1 Mass: not exceeding 20 kg/m 2 20-30 kg/m 3 30-40 kg/m 4 40-50 kg/m 5 exceeding 50 kg/m 1 Timber 2 Concrete 1 Chairs 2 Baseplates 3 Pandrol rail fastenings 4 Plain fishplates 5 Insulated fishplates 6 Conductor rail insulators 7 Conductor rail side ramps
5 Supplying	1 Turnouts nr 2 Diamond crossings nr 8 Sundries	1 Buffer stops nr 2 Retarders nr 3 Wheel stops nr 4 Lubricators nr 5 Switch heaters nr 6 Switch levers nr 7 Conductor rail guard boards m

CLASS S

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 The volume of <i>top ballast</i> measured shall include the volume occupied by sleepers.</p> <p>M2 The areas of additional <i>waterproof membranes</i> in laps shall not be measured.</p>	<p>D1 <i>Bottom ballast</i> shall be ballast placed before the track is laid.</p> <p>D2 <i>Top ballast</i> shall be ballast placed after the track is laid.</p>		<p>A1 Item descriptions for <i>track foundations</i> shall state the material.</p> <p>A2 Item descriptions for <i>blinding, blankets and waterproof membranes</i> shall state their thickness.</p>
<p>M3 The length of <i>taking up plain track</i> shall be measured along the centre line of the track (two rail) and shall exclude lengths occupied by turnouts and diamond crossings.</p> <p>M4 The lengths of <i>taking up check, guard and conductor rails</i> shall be measured along the lengths of the rail (one rail) and shall exclude lengths within turnouts and diamond crossings.</p>		<p>C1 Items for <i>taking up turnouts and diamond crossings</i> shall be deemed to include check, guard and conductor rails.</p>	<p>A3 Item descriptions for <i>taking up track</i> shall state the amount of dismantling, details of disposal of the track and the type of rail, sleeper and joint.</p> <p>A4 Item descriptions for <i>taking up buffer stops</i> shall state their approximate weight and type of construction.</p>
	<p>D3 The length of track stated in item descriptions for <i>lifting, packing and slewing track</i> shall be the length measured along the centre line of the track (two rail) and shall be taken over all roads. Switch roads shall be measured from the toes of switches.</p>	<p>C2 Items for <i>lifting, packing and slewing track</i> shall be deemed to include opening out, packing and boxing in with ballast and insertion of closure rails.</p>	<p>A5 Item descriptions for <i>lifting, packing and slewing track</i> shall state the length of track, the maximum distance of slew and the maximum lift.</p> <p>A6 Where extra ballast is required item descriptions for <i>lifting, packing and slewing</i> shall so state.</p>
<p>M5 The mass measured for <i>supplying rails</i> shall include the mass of twist rails.</p> <p>M6 <i>Fishplates</i> shall be measured by the number of pairs.</p>		<p>C3 Items for <i>supplying</i> shall be deemed to include delivery of components to the Site.</p> <p>C4 Items for <i>supplying sleepers</i> shall be deemed to include fittings attached by the supplier.</p> <p>C5 Items for <i>supplying fittings</i> shall be deemed to include fixings, keys, clips, bolts, nuts, screws, spikes, ferrules, track circuit insulators, pads and conductor rail insulator packings.</p>	<p>A7 Item descriptions for <i>supplying sleepers and fittings</i> shall state the type.</p> <p>A8 Items for <i>supplying sleepers</i> shall state the size of the sleepers and identify the fittings which are attached by the supplier.</p> <p>A9 Item descriptions for <i>supplying rails</i> shall state either the section reference and the mass per metre or the cross-sectional dimensions and the mass per metre.</p>
<p>M7 <i>Conductor rail guard boards</i> shall be measured each side of the rail.</p>		<p>C3 Items for <i>supplying</i> shall be deemed to include delivery of components to the Site.</p> <p>C6 Items for <i>supplying turnouts and diamond crossings</i> shall be deemed to include timbers, fittings and check rails.</p> <p>C7 Items for <i>supplying conductor rail guard boards</i> shall be deemed to include fixings.</p>	<p>A10 Item descriptions for <i>supplying turnouts and diamond crossings</i> shall state the type.</p> <p>A11 Item descriptions for <i>supplying sundries</i> shall state the type.</p> <p>A12 Item descriptions for <i>supplying buffer stops</i> shall state their approximate weight.</p>

CLASS S

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
6 Laying	1 Bullhead rails 2 Flat bottom rails 3 Dock rails 4 Crane rails	1 Plain track m 2 Form curve in plain track radius not exceeding 300 m m 3 Form curve in plain track radius exceeding 300 m m 4 Turnouts nr 5 Diamond crossings nr 7 Welded joints nr 8 Spot re-sleeping nr
	5 Check rails 6 Guard rails 7 Conductor rails	1 Rail m 2 Length ends nr 3 Side ramps nr 7 Welded joints nr
	8 Sundries	1 Buffer stops nr 2 Retarders nr 3 Wheel stops nr 4 Lubricators nr 5 Switch heaters nr 6 Switch levers nr 7 Conductor rail guard boards m

CLASS S

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M8 The length of <i>laying plain track</i> shall be measured along the centre line of the track (two rail) and shall include the lengths occupied by turnouts and diamond crossings.</p>	<p>D4 <i>Spot re-sleeping</i> shall be replacing sleepers in pre-fabricated track not supplied by the Contractor.</p>	<p>C8 Items for <i>laying</i> shall be deemed to include work carried out after delivery of components to the Site or, where track is not to be supplied by the Contractor, to the location stated in accordance with rule A13.</p>	<p>A13 Item descriptions for <i>laying rail track</i> which is not to be supplied by the Contractor shall state the form in which it is to be supplied and the location.</p>
<p>M9 The lengths of <i>laying check, guard and conductor rails</i> shall be measured along the lengths of the rail (one rail).</p>		<p>C9 Items for <i>laying</i> shall be deemed to include laying sleepers, fittings, twist rails and short lengths between turnouts and diamond crossings.</p>	<p>A14 Item descriptions for <i>laying plain track</i> shall identify pre-fabricated lengths.</p>
<p>M7 <i>Conductor rail guard boards</i> shall be measured each side of the rail.</p>		<p>C10 Items for <i>laying switches and crossings</i> shall be deemed to include laying check rails.</p>	<p>A15 Item descriptions for <i>laying rails</i> shall state the type and mass per metre of rail and the type of joint and sleeper.</p>
			<p>A16 Item descriptions for <i>laying turnouts and diamond crossings</i> shall state their type and length.</p>
			<p>A17 Item descriptions for <i>welded joints</i> shall state the rail section and the type of weld.</p>
			<p>A18 Item descriptions for <i>laying buffer stops</i> shall state their approximate weight.</p>

CLASS T: TUNNELS

Includes: Excavation, lining and securing of tunnels, shafts and other subterranean cavities
 Excludes: Geotechnical processes carried out from the ground surface (included in class C)
 Filling within tunnels (included in class E)
 Reinforcement in in situ lining (included in class G)
 Pipe laying in headings, tunnels and shafts (included in classes I, J, K and L)
 Cut and cover tunnels

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Excavation	1 Tunnels in rock m^3	1 Stated diameter: not exceeding 2 m
	2 Tunnels in other stated material m^3	2 2-3 m
	3 Shafts in rock m^3	3 3-4 m
	4 Shafts in other stated material m^3	4 4-5 m
	5 Other cavities in rock m^3	5 5-6 m
	6 Other cavities in other stated material m^3	6 6-7 m
		7 7-8 m
		8 exceeding 8 m
	7 Excavated surfaces in rock m^2	
	8 Excavated surfaces in other stated material m^2	

CLASS T

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Tunnels constructed by cut and cover are excluded from this class. The earthworks, in situ concrete and other components of tunnels constructed by cut and cover shall be classed appropriately.</p>	<p>D1 Transitions, breakaways and interconnections between tunnels and shafts which include work outside the normal profiles of the tunnels and shafts shall be classed as <i>other cavities</i>.</p>		<p>A1 Where tunnelling work is expressly required to be executed under compressed air, items shall be so described. Item descriptions shall state the gauge pressure in stages. The first stage shall be gauge pressure not exceeding 1 bar. Subsequent stages shall be gauge pressures in increments of 0.4 bars. The provision and operation of plant and services associated with the use of compressed air shall be classed as <i>specified requirements</i> in class A.</p> <p>A2 Item descriptions for excavation and lining of <i>other cavities</i> shall identify the cavity.</p>
<p>M2 The volume measured for excavation shall be calculated to the payment lines shown on the Drawings or, where no payment lines are shown, to the net dimensions of the volumes to be excavated. Excavation (other than overbreak) outside the normal cross-sectional profile of tunnels and shafts shall be classed as <i>excavation of other cavities</i>.</p> <p>M3 An isolated volume of rock occurring within other material to be excavated shall not be measured separately unless its volume exceeds 0.25 m³.</p> <p>M4 The area measured for excavated surfaces shall be the area of the payment surfaces shown on the Drawings or, where no payment surfaces are shown, the net areas of the surfaces of the volumes to be excavated.</p>	<p>D2 The diameter used for classification and stated in item descriptions shall be the external diameter of the excavation cross-section of <i>tunnels, shafts and other cavities</i>.</p>	<p>C1 Items for <i>excavation</i> shall be deemed to include disposal of excavated material off the Site and removal of dead services unless otherwise stated in item descriptions.</p>	<p>A3 Item descriptions for excavation shall state whether tunnels and shafts are straight, curved or tapered. Item descriptions for excavation shall state the gradient of tunnels sloping at a gradient of 1 in 25 or steeper and the inclination to the vertical of inclined shafts.</p> <p>A4 Where material is for disposal on the Site the location of the disposal areas shall be stated in item descriptions for excavation. Where excavated material is to be used as filling, item descriptions shall so state.</p> <p>A5 Details of filling for voids caused by overbreak shall be stated in item descriptions for <i>excavated surfaces</i>.</p> <p>A6 Where tunnels, shafts and <i>other cavities</i> are not of circular cross-section, their maximum external dimension of cross-section shall be substituted for the diameter and their external cross-sectional dimensions shall be stated in item descriptions.</p>

CLASS T

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
2 In situ lining to tunnels	1 Sprayed concrete primary m ²	1 Stated diameter: not exceeding 2 m
3 In situ lining to shafts	2 Sprayed concrete secondary m ²	2 2-3 m
4 In situ lining to other cavities	3 Cast concrete primary m ³	3 3-4 m
	4 Cast concrete secondary m ³	4 4-5 m
	5 Formwork to stated finish m ²	5 5-6 m
		6 6-7 m
5 Preformed segmental lining to tunnels	1 Precast concrete bolted rings nr	7 7-8 m
6 Preformed segmental lining to shafts	2 Precast concrete expanded rings nr	8 exceeding 8 m
7 Preformed segmental lining to other cavities	3 Cast iron bolted rings nr	
	4 Cast iron expanded rings nr	
	5 Nodular iron rings nr	
	6 Fabricated steel rings nr	
	7 Lining ancillaries	1 Parallel circumferential packing
		2 Tapered circumferential packing
		3 Stepped junctions
		4 Caulking of stated material

(see rules at head of class on page 83)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M5 The thickness of <i>in situ</i> lining shall be measured to the payment lines shown on the Drawings or, where no payment lines are shown, to the net dimensions of the volumes to be lined (see rule M2).</p>	<p>D3 Reinforcing materials added to the mix for <i>sprayed concrete</i> shall not be classed as reinforcement.</p> <p>D4 The diameter of lining used for classification and stated in item descriptions shall be the internal diameter.</p>	<p>C2 Items for lining shall be deemed to include joints and finishes.</p> <p>C3 Items for <i>preformed lining</i> shall be deemed to include reinforcement and formwork.</p>	<p>A7 Item descriptions for lining shall state whether tunnels and shafts are straight, curved or tapered. Item descriptions for lining shall state the gradient of tunnels sloping at a gradient of 1 in 26 or steeper and the inclination to the vertical of inclined shafts.</p> <p>A8 Item descriptions for <i>in situ</i> lining shall state the specification of the concrete and whether it is reinforced and identify those linings which are to form head walls, shaft bottoms and other similar components. Item descriptions for <i>sprayed concrete lining</i> shall state the minimum thickness.</p> <p>A9 Item descriptions for <i>preformed segmental lining rings</i> shall identify the components of each ring and state the nominal ring width and the maximum piece weight.</p> <p>A10 Item descriptions for <i>preformed segmental lining</i> in pilot tunnels or shafts shall so state. Where the materials used in <i>preformed segmental lining</i> to pilot tunnels and shafts are to remain the property of the Employer item descriptions shall so state.</p> <p>A11 Item descriptions for <i>precast concrete segmental lining rings</i> shall state whether the segments are flanged or solid. Item descriptions for metal <i>segmental lining rings</i> which have machined abutting surfaces shall so state.</p> <p>A12 The internal diameter of the lining shall be stated in item descriptions for <i>lining ancillaries</i>.</p> <p>A13 Where linings are not of circular cross-section their maximum internal dimension of cross-section shall be substituted for the diameter and their internal cross-sectional dimensions shall be stated in item descriptions.</p>
<p>M6 The volume of <i>in situ</i> cast concrete lining shall be calculated as set out in class F.</p>			
<p>M7 The measurement unit for packing shall be the number of rings of segments packed.</p>			

NOTE

Concrete work in lining to tunnels, shafts and other cavities which involves other than simple shapes may be classed as concrete (class F) and concrete ancillaries (class G).

CLASS T

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
8 Support and stabilization	1 Rock bolts m	1 Mechanical 2 Mechanical grouted 3 Pre-grouted impacted 4 Chemical and anchor 5 Chemical grouted 6 Chemically filled
	2 Internal support	1 Steel arches: supply 2 erection 3 Timber supports: supply 4 erection 5 Lagging 6 Sprayed concrete 7 Mesh or link
	3 Pressure grouting	1 Sets of drilling and grouting plant 2 Face packers 3 Deep packers of stated size 4 Drilling and flushing to stated diameter 5 Re-drilling and flushing 6 Injection of grout materials of stated composition
	4 Forward probing m	

CLASS T

(see rules at head of class on page 83)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M8 Both temporary and permanent <i>support and stabilization</i> shall be measured.</p> <p>M9 The mass measured for <i>steel arches</i> shall be calculated as set out in class M. The volume of <i>timber support</i> measured shall be the volume of support in timber components calculated as set out in class O. The area of <i>sprayed concrete support</i> shall be measured at the payment lines shown on the Drawings or, where no payment lines are shown, to the net dimensions of the support to be provided.</p> <p>M10 The number of <i>face packers</i> and <i>deep packers</i> measured shall be the number of injections.</p> <p>M11 The mass measured for <i>injection of grout materials</i> shall not include the mass of mixing water.</p>	<p>D3 Reinforcing materials added to the mix for <i>sprayed concrete</i> shall not be classed as reinforcement.</p> <p>D5 Mesh or link reinforcement in <i>sprayed concrete support</i> shall be classed as mesh or link support.</p>	<p>C4 Items for <i>face packers</i> shall be deemed to include collaring, securing and making good linings on completion.</p>	<p>A14 Item descriptions for <i>rock bolts</i> shall state their size, type, shank detail and maximum length.</p> <p>A15 The materials used for lagging and for packing or grouting behind lagging shall be stated in item descriptions.</p> <p>A16 Item descriptions for <i>sprayed concrete support</i> shall state the specification of the concrete and whether it is reinforced and the minimum thickness. Item descriptions for <i>mesh or link support</i> shall state the size and mass of mesh or link fabric.</p> <p>A17 The lengths of holes shall be stated in stages of 5 m in item descriptions for <i>drilling and re-drilling holes for pressure grouting</i> and in item descriptions for <i>forward probing</i>.</p>

CLASS U: BRICKWORK, BLOCKWORK AND MASONRY

Excludes: Brickwork in manholes and other brickwork incidental to pipework (included in class K)
Brickwork in sewer renovation (included in class Y)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Common brickwork 2 Facing brickwork 3 Engineering brickwork 4 Lightweight blockwork 5 Dense concrete blockwork 6 Artificial stone blockwork 7 Ashlar masonry 8 Rubble masonry	1 Thickness: not exceeding 150 mm m^2 2 150–250 mm m^2 3 250–500 mm m^2 4 500 mm–1 m m^2 5 exceeding 1 m m^3 6 Columns and piers of stated cross-sectional dimensions m	1 Vertical straight walls 2 Vertical curved walls 3 Battered straight walls 4 Battered curved walls 5 Vertical facing to concrete 6 Battered facing to concrete 7 Casing to metal sections
	7 Surface features	1 Copings and sills, material stated m 2 Rebates and chases m 3 Cornices m 4 Band courses m 5 Corbels m 6 Pilasters m 7 Plinths m 8 Fair facing m
	8 Ancillaries	1 Joint reinforcement m 2 Damp proof courses m 3 Movement joints m 4 Bonds to existing work m^2 5 Infills of stated thickness m^2 6 Fixings and ties m^2 7 Built-in pipes and ducts, cross-sectional area: not exceeding 0.05 m^2 m 8 stated exceeding 0.05 m^2 m

CLASS U

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Each skin of brickwork, blockwork or masonry which is in cavity or composite construction shall be measured.</p> <p>M2 Volumes and areas measured for brickwork, blockwork and masonry shall include the volumes and areas of joints, and exclude those of copings and sills. No deduction from or addition to volumes and areas measured shall be made for intruding or projecting surface features. No deduction from the volumes and areas measured shall be made for holes and openings in walls or surfaces each not exceeding 0.25 m² in cross-sectional area.</p>			
<p>M3 Mean dimensions shall be used to calculate the areas and volumes of walls, facing to concrete and casing to metal sections and the heights of columns and piers.</p>	<p>D1 Walls or facing battered on one or both sides shall be classed as <i>battered walls or battered facing</i>.</p> <p>D2 Isolated walls having a length on plan not exceeding four times their thickness shall be classed as <i>piers</i>.</p> <p>D3 In determining the thicknesses of walls, facing and casing, the presence of surface features shall be ignored.</p> <p>D4 The thicknesses of <i>battered walls</i> shall be their mean thicknesses.</p>	<p>C1 Items for masonry shall be deemed to include fair facing.</p>	<p>A1 Item descriptions for walls, facing to concrete, casing to metal sections, columns and piers shall either state the materials, nominal dimensions and types of brick, block and stone or give equivalent references to applicable British Standard specifications.</p> <p>A2 Item descriptions for masonry walls, facing to concrete, casing to metal sections, columns and piers shall state the surface finish.</p> <p>A3 The bonding pattern, type of mortar and type of jointing and pointing shall be stated in item descriptions for walls, facing to concrete, casing to metal sections, columns and piers.</p> <p>A4 Item descriptions for walls, facing to concrete, casing to metal sections, columns and piers which are in cavity or composite construction shall so state.</p> <p>A5 The nominal thickness of walls, facing to concrete and casing to metal sections shall be stated in item descriptions.</p>
<p>M4 The lengths of surface features measured shall be mean lengths. The areas measured for fair facing shall be those expressly required and shall be measured at the face.</p>	<p>D5 Columns and piers attached to walls or facing of the same material shall be classed as <i>pilasters</i>.</p>		<p>A6 Item descriptions for surface features shall include sufficient detail to identify special masonry and special or cut bricks and blocks. The spacing of intermittent surface features shall be stated in item descriptions.</p> <p>A7 The cross-sectional dimensions of surface features shall be stated in item descriptions where the cross-sectional area of the surface feature exceeds 0.05 m².</p>
<p>M5 The length of additional material in caps of joint reinforcement and damp proof courses shall not be measured.</p> <p>M6 The areas of fixings and ties measured shall be the areas of brickwork, blockwork or masonry fixed or tied. Where two areas of brickwork, blockwork or masonry are fixed or tied to each other, only the smaller of the two areas shall be measured.</p>		<p>C2 Items for built-in pipes and ducts shall be deemed to include their supply unless otherwise stated.</p>	<p>A8 The materials and dimensions of joint reinforcement and damp proof courses, the materials of infills and the type and spacing of fixings and ties shall be stated in item descriptions.</p> <p>A9 The dimensions and nature of components including face or internal details shall be stated in item descriptions for movement joints.</p> <p>A10 The lengths of built-in pipes and ducts shall be stated in item descriptions where they exceed 1 m.</p>

CLASS V: PAINTING

Includes: In situ painting

Excludes: Painting carried out prior to delivery of components to the Site

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Lead, iron or zinc based primer paint 2 Etch primer paint 3 Oil paint 4 Alkyd gloss paint 5 Emulsion paint 6 Cement paint 7 Epoxy or polyurethane paint 8 Bituminous or coal tar paint	1 Metal, other than metal sections and pipework 2 Timber 3 Smooth concrete 4 Rough concrete 5 Masonry 6 Brickwork and blockwork 7 Metal sections m ² 8 Pipework m ²	1 Upper surfaces inclined at an angle not exceeding 30° to the horizontal m ² 2 Upper surfaces inclined at 30°-60° to the horizontal m ² 3 Surfaces inclined at an angle exceeding 60° to the horizontal m ² 4 Soffit surfaces and lower surfaces inclined at an angle not exceeding 60° to the horizontal m ² 5 Surfaces of width not exceeding 300 mm m 6 Surfaces of width 300 mm-t m 7 Isolated groups of surfaces ar

CLASS V

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
M1 No deduction from the areas measured shall be made for holes and openings in the painted surfaces each not exceeding 0.5 m ² in area.		C1 Items for painting shall be deemed to include preparation of surfaces before painting.	A1 Item descriptions for painting shall state the material used and either the number of coats or the film thickness. A2 Preparation of surfaces shall be identified in item descriptions where more than one type of preparation is specified for the same surface.
M2 Surfaces of width not exceeding 1 m shall not be distinguished by inclination.			
M3 <i>Isolated groups of surfaces</i> of different shape or dimensions shall be measured as separate items.	D1 <i>Isolated groups of surfaces</i> shall be classed as such only where the total surface area of each group does not exceed 6 m ² .		A3 Item descriptions for <i>isolated groups of surfaces</i> shall identify the work to be painted and its location.
M4 In calculating the painted area of <i>metal sections</i> the presence of connecting plates, brackets, rivets, bolts, nuts and similar projections shall be ignored. M5 The area measured for painting <i>pipework</i> shall be the length multiplied by the girth of each length of pipe or lagged pipe with no deductions or additions for flanges, valves, other projecting fittings and hangers.		C2 Painting of <i>metal sections</i> shall be deemed to include painting the surfaces of connecting plates, brackets, rivets, bolts, nuts and similar projections. C3 Painting of <i>pipework</i> shall be deemed to include painting the surfaces of flanges, valves, other projecting fittings and hangers.	

NOTE

Painting may be measured by the number of *isolated groups of surfaces* of the same shape and dimensions instead of by the length or area of the separate surfaces.

CLASS W: WATERPROOFING

Includes: Damp proofing, tanking and roofing

Excludes: Waterproofed joints (included in classes C, G, H, I, J, K, R, T, U, X and Y)

Damp proof courses in brickwork, blockwork and masonry (included in class U)

Surface finishes and linings in simple building works incidental to civil engineering works (included in class Z)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Damp proofing 2 Tanking 3 Roofing	1 Asphalt 2 Sheet metal 3 Waterproof sheeting 4 Waterproof coating 5 Rendering in ordinary cement mortar 6 Rendering in waterproof cement mortar 7 Tiles	1 Upper surfaces inclined at an angle not exceeding 30° to the horizontal 2 Upper surfaces inclined at 30°-60° to the horizontal 3 Surfaces inclined at an angle exceeding 60° to the horizontal 4 Curved surfaces 5 Dorned surfaces 6 Surfaces of width not exceeding 300 mm 7 Surfaces of width 300 mm-1 m B Isolated groups of surfaces
4 Protective layers	1 Sand asphalt 2 Flexible sheeting 3 Sand 4 Sand and cement screed 5 Tiles	1 Upper surfaces inclined at an angle not exceeding 30° to the horizontal 2 Upper surfaces inclined at 30°-60° to the horizontal 3 Surfaces inclined at an angle exceeding 60° to the horizontal 4 Curved surfaces 5 Dorned surfaces 6 Surfaces of width not exceeding 300 mm 7 Surfaces of width 300 mm-1 m 8 Isolated groups of surfaces
5 Sprayed or brushed waterproofing m ²		

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
M1 The areas measured shall be those of the surfaces covered, no deduction from the areas measured shall be made for holes and openings in the waterproofed surfaces each not exceeding 0.5 m ² in area.		C1 Items for waterproofing shall be deemed to include preparing surfaces, forming joints, overlaps, mitres, angles, fillets, built-up edges and laying to falls or cambers.	A1 Item descriptions for waterproofing shall state the materials used and the number and thickness of coatings or layers.
M2 Surfaces of width not exceeding 1 m shall not be distinguished by inclination or by curvature. M3 Waterproofing classed as to <i>curved or domed surfaces</i> shall not be distinguished by inclination.	D1 Waterproofing shall be classed as to <i>curved or domed surfaces</i> only where a radius of curvature of the surface is less than 10 m.		
M4 <i>Isolated groups of surfaces</i> of different shape or dimensions shall be measured as separate items.	D2 <i>Isolated groups of surfaces</i> shall be classed as such only where the total surface area of each group does not exceed 6 m ² .		A2 Item descriptions for <i>isolate groups of surfaces</i> shall identify the work to be waterproofed and state its location.
M2 Surfaces of width not exceeding 1 m shall not be distinguished by inclination or by curvature. M3 Waterproofing classed as to <i>curved or domed surfaces</i> shall not be distinguished by inclination.	D1 Waterproofing shall be classed as to <i>curved or domed surfaces</i> only where a radius of curvature of the surface is less than 10 m.		
M4 <i>Isolated groups of surfaces</i> of different shape or dimensions shall be measured as separate items.	D2 <i>Isolated groups of surfaces</i> shall be classed as such only where the total surface area of each group does not exceed 6 m ² .		A2 Item descriptions for <i>isolate groups of surfaces</i> shall identify the work to be waterproofed and state its location.

NOTE

Waterproofing may be measured by the number of *isolated groups of surfaces* of the same shape and dimensions instead of by the length or area of the separate surfaces.

CLASS X: MISCELLANEOUS WORK

Includes: Fences, gates and their foundations
 Drainage to structures above ground
 Rock filled gabions

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Fences m	1 Timber post and rail 2 Timber post and wire 3 Concrete post and wire 4 Metal post and wire 5 Coated metal post and wire 6 Timber close boarded 7 Metal guard rails 8 Metal crash barriers	1 Height: not exceeding 1 m 2 1-1.25 m 3 1.25-1.5 m 4 1.5-2 m 5 2-2.5 m 6 2.5-3 m 7 exceeding 3 m
2 Gates and stiles nr	1 Timber field gates 2 Timber wicket gates 3 Metal field gates 4 Metal wicket gates 5 Stiles	1 Width: not exceeding 1.5 m 2 1.5-2 m 3 2-2.5 m 4 2.5-3 m 5 3-4 m 6 4-5 m 7 exceeding 5 m
3 Drainage to structures above ground	1 Mild steel 2 Cast iron 3 Plastics 4 Asbestos cement	1 Gutters m 2 Fittings to gutters nr 3 Downpipes m 4 Fittings to downpipes nr
4 Rock filled gabions	1 Box of stated size nr 2 Mattress of stated thickness m ²	

CLASS X

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
M1 Lengths of fences shall exclude lengths occupied by gates and stiles.	D1 The heights used for classification of fences shall be measured from the Commencing Surface.	C1 Items for fences shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling, removal of existing services, concrete, formwork and reinforcement. C2 Items for fences shall be deemed to include end posts, angle posts, straining posts and gate posts.	A1 Item descriptions for fences which are erected to a curve of radius not exceeding 100 m or on a surface inclined at an angle exceeding 10° shall so state. A2 The types and principal dimensions of fences and of their foundations shall be stated in item descriptions.
	D2 The width used for classification of gates and stiles shall be measured between the inside faces of posts.		A3 The types and principal dimensions of gates and stiles shall be stated in item descriptions. A4 Item descriptions for gates composed of more than one leaf shall identify the number of leaves in item descriptions.
	D3 Fittings to gutters shall include bends, angles, stop ends and outlets. Fittings to downpipes shall include bends, swan necks, shoes and roof outlets fixed directly to downpipes.	C3 Items for drainage to structures above ground shall be deemed to include supports.	A5 Item descriptions for drainage to structures above ground shall state the type, principal dimensions and materials of the components.
	D4 Rock filled gabions exceeding 300 mm thick shall be classed as box gabions and those not exceeding 300 mm thick as mattress gabions. Filling shall be deemed to be imported unless otherwise stated.		A6 Item descriptions for rock filled gabions shall state the type and grading of filling, the size of mesh and the diameter of mesh wire. Details of protective coatings shall be stated.

CLASS Y: SEWER AND WATER MAIN RENOVATION AND ANCILLARY WORKS

Includes: Preparation and renovation of existing sewers and water mains
New manholes within the length of existing sewers
Work to existing manholes

Excludes: Grouting carried out from outside the sewer (included in class C)
New pipework (included in classes I-L)
New fittings and valves used in water main renovation (included in class J)
Extras to excavation and backfilling for new manholes and other chambers (included in class L)

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Preparation of existing sewers	1 Cleaning m	
	2 Removing intrusions nr	1 Laterals, bore not exceeding 150 mm 2 Laterals, stated profile and size exceeding 150 mm in one or more dimension 3 Other stated artificial intrusions
	3 Closed-circuit television surveys m	
	4 Plugging laterals, materials stated nr 5 Filling laterals and other pipes, materials stated m ³	1 Bore not exceeding 300 mm 2 Stated profile and size exceeding 300 mm in one or more dimension
	6 Local internal repairs nr	1 Area: not exceeding 0.1 m ² 2 0.1-0.25 m ² 3 stated exceeding 0.25 m ²
	2 Stabilization of existing sewers	1 Pointing, materials stated m ² 2 Pipe joint sealing, materials stated nr
3 External grouting		1 Number of holes nr 2 Injection of grout, materials stated m ³

CLASS Y

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M1 Lengths of sewers shall be measured along their centre lines between the inside surfaces of manholes but shall exclude lengths occupied by pipes and fittings comprising backdrops to manholes.</p> <p>M2 Where work is expressly required to be carried out by excavation, crossings, reinstatement and other pipework and ancillaries shall be measured in class K and extras to excavation and backfilling shall be measured in class L.</p>		<p>C1 Items for work which is expressly required to be carried out by excavation shall be deemed to include preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling and removal of dead services.</p>	<p>A1 The location of the work in each item or group of items shall be stated so that the work can be identified by reference to the Drawings.</p> <p>A2 Principal dimensions and profiles of sewers shall be stated in item descriptions.</p> <p>A3 Work which is expressly required to be carried out manually or by remotely controlled methods shall each be so stated in item descriptions.</p> <p>A4 Item descriptions shall identify work which is expressly required to be carried out by excavation and (except for manholes) shall state the maximum depth of excavation in stages of 1 m measured to the invert of the sewer or water main.</p> <p>A5 Item descriptions for <i>preparation, stabilization, renovation and laterals</i> shall state the material forming the existing sewer or water main.</p>
		<p>C2 Items for <i>cleaning</i> shall be deemed to include making good resultant damage.</p>	
	<p>D1 Items shall be classed as <i>removing intrusions</i> where intrusions into the bords of existing sewers are to be removed prior to renovation.</p>	<p>C3 Items for <i>removing intrusions</i> shall be deemed to include making good.</p>	<p>A6 Item descriptions for <i>removing intrusions</i> shall state the materials forming the intrusions.</p>
	<p>D2 The areas stated in item descriptions for <i>local internal repairs</i> shall be the finished surface areas.</p>	<p>C4 Items for <i>local internal repairs</i> shall be deemed to include cutting out and repointing.</p>	
<p>M3 No deduction shall be made from the areas of sewer surfaces measured for <i>pointing</i> for openings or voids each not exceeding 0.5 m² in area.</p>		<p>C5 Items for <i>pointing and pipe joint sealing</i> shall be deemed to include preparation of joints.</p>	
<p>M4 <i>External grouting</i> shall be measured only where grouting is expressly required to be carried out as a separate operation from annulus grouting (Y 3 B D).</p>	<p>D3 <i>External grouting</i> shall be grouting of voids outside the existing sewer from within the existing sewer other than voids grouted in the course of annulus grouting.</p>		<p>A7 Where <i>external grouting</i> is carried out through pipe joints, descriptions of items for the number of holes shall so state.</p>

CLASS Y

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
3 Renovation of existing sewers	1 Sliplining m	1 Polyethylene 2 Polypropylene
	2 In situ jointed pipe lining m	1 Polyethylene 2 Polypropylene 3 Glass reinforced plastic
	3 Segmental lining m	3 Glass reinforced plastic 4 Glass reinforced concrete 5 Cast gunitite 6 Resin concrete
	4 Stated proprietary lining m	
	5 Gunitite coating of stated thickness m	
	6 Annulus grouting, materials stated m ³	
4 Laterals to renovated sewers	1 Jointing nr	1 Bore: not exceeding 150 mm 2 150-300 mm 3 Stated profile and size exceeding 300 mm in one or more dimension
	2 Flap valves of stated size nr	1 Remove existing 2 Replace existing 3 New flap valve of stated type
5 Water main renovation and ancillary works	1 Clearing m 2 Removing intrusions nr 3 Pipe sample inspections nr 4 Closed-circuit television surveys m 5 Cement mortar lining m 6 Epoxy lining m	1 Nominal bore: not exceeding 200 mm 2 200-300 mm 3 300-600 mm 4 600-900 mm 5 900-1200 mm 6 stated exceeding 1200 mm
6 New manholes nr	1 Brick 2 Brick with backdrop 3 In situ concrete 4 In situ concrete with backdrop 5 Precast concrete 6 Precast concrete with backdrop	1 Depth: not exceeding 1.5 m 2 1.5-2 m 3 2-2.5 m 4 2.5-3 m 5 3-3.5 m 6 3.5-4 m 7 stated exceeding 4 m
7 Existing manholes nr	1 Abandonment 2 Alteration	

CLASS Y

(see rules at head of class on page 97)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
			<p>A8 Item descriptions for <i>slip-lining, in situ jointed pipe lining, segmental lining and stated proprietary lining</i> shall state the type of lining, its minimum finished internal size and its thickness or grade.</p> <p>A9 Item descriptions for <i>in situ jointed pipe lining and segmental lining</i> shall state the offset where the lining is curved to an offset which exceeds 35 mm per metre.</p>
<p>M5 The volume measured for <i>annulus grouting</i> shall not include the volume measured for external grouting (Y 2 3 2).</p>	<p>D4 <i>Annulus grouting</i> shall be grouting of the annular voids between new linings and existing sewers and of other voids grouted in the course of grouting annular voids.</p>		
		<p>C6 Items for laterals shall be deemed to include the work involved in connecting to the lining within 1 m from the inside face of the lined sewer.</p>	<p>A10 Item descriptions for <i>jointing laterals</i> shall state the type of lining to which the laterals are to be connected and identify those laterals which are to be regraded.</p>
<p>M6 Lengths of water mains shall be measured along their centre lines and shall include lengths occupied by fittings and valves.</p>	<p>D5 <i>Pipe sample inspections and closed-circuit television surveys</i> shall include work carried out either before or after cleaning and lining.</p>	<p>C7 Items for <i>pipe sample inspections</i> shall be deemed to include replacing the length removed by new pipework.</p>	<p>A11 Item descriptions for <i>lining</i> shall state the materials, nominal bores and thicknesses of the lining.</p>
	<p>D6 The depth of <i>manholes</i> shall be measured from the tops of covers to channel inverts or tops of base slabs, whichever is the lower.</p>	<p>C8 Items for <i>new manholes</i> shall be deemed to include excavation, preparation of surfaces, disposal of excavated material, upholding sides of excavation, backfilling, concrete, reinforcement, formwork, joints, finishes and reinstatement.</p> <p>C9 Items for <i>new manholes</i> shall be deemed to include all items of metalwork and pipework which occur within or at the surface of the manhole.</p> <p>C10 Items for <i>new manholes</i> with backdrops shall be deemed to include the pipes and fittings comprising the backdrop.</p> <p>C11 Items for <i>new manholes</i> which replace existing manholes shall be deemed to include breaking out and disposal of existing manholes.</p>	<p>A12 Type or mark numbers shall be stated in item descriptions for <i>manholes</i> of which details are given elsewhere in the Contract. Item descriptions shall identify different configurations of manholes.</p> <p>A13 Types and loading duties of covers shall be stated in item descriptions for <i>new manholes</i>.</p> <p>A14 Item descriptions shall separately identify <i>new manholes</i> which replace existing manholes.</p> <p>A15 Item descriptions for <i>existing manholes</i> shall state details of the work required.</p>

NOTE

Manholes may be measured in detail as set out in other classes of CES.MM3.

CLASS Y

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
8 Interruptions	h 1 Preparation of existing sewers 2 Stabilization of existing sewers	
	3 Renovation of existing sewers	1 Sliplining 2 In situ jointed pipe lining 3 Segmental lining 4 Stated proprietary lining 5 Gunite coating 6 Annulus grouting
	4 Work on laterals to renovated sewers 5 Work on manholes	

CLASS Y

(see rules at head of class on page 97)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M7 <i>Interruptions</i> shall be measured only where a minimum pumping capacity is expressly required and for periods of time during normal working hours when the flow in the sewer exceeds the installed pumping capacity and work is interrupted.</p>			

CLASS 2: SIMPLE BUILDING WORKS INCIDENTAL TO CIVIL ENGINEERING WORKS

Includes: Carpentry and joinery
 Insulation
 Windows, doors and glazing
 Surface finishes, linings and partitions
 Piped building services
 Ducted building services
 Cabled building services

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
1 Carpentry and joinery	1 Structural and carcassing timber	1 Floors 2 Walls and partitions 3 Flat roofs 4 Pitched roofs 5 Plates and bearers 6 Struts 7 Creats 8 Trussed rafters and roof trusses
	2 Strip boarding 3 Sheet boarding	1 Floors 2 Sipping upper surfaces 3 Walls 4 Soffits
	4 Stairs and walkways	1 Stairways and landings 2 Walkways and platforms 3 Isolated balustrades 4 Ladders
	5 Miscellaneous joinery	1 Skirtings 2 Architraves 3 Trims 4 Shelves
	6 Units and fittings	1 Base units 2 Wall units 3 Work tops 4 Notice-boards
2 Insulation	1 Sheets 2 Quilts 3 Boards 4 Loose fill	1 Floors 2 Sloping upper surfaces 3 Walls 4 Soffits
3 Windows, doors and glazing	1 Timber 2 Metal 3 Plastics	1 Windows 2 Window sub-frames 3 Doors 4 Frames or lining sets 5 Screens and borrowed lights 6 Roof lights
	4 Ironmongery	1 Hinges 2 Door closers 3 Locks 4 Bolts 5 Handles 6 Plates 7 Brackets

(continued)

CLASS Z

Excludes: Drainage below ground (included in classes I-L)
 Ducts and trenches for electrical services below ground or outside the building (included in classes I-L)
 Metalwork (included in class N)
 Civil engineering timber works (included in class O)
 Brickwork, blockwork and masonry (included in class U)
 Painting (included in class V)
 Asphalt work (included in class W)
 Roofing, cladding and coverings (included in class W)
 Drainage to structures above ground (included in class X)

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES										
<p>M1 The lengths and areas measured for <i>carpentry and joinery</i> items shall be measured net with no allowance for joints or laps.</p> <p>M2 No deduction from the areas measured shall be made for holes and openings each not exceeding 0.5 m² in area.</p> <p>M3 <i>Struts</i> between joists shall be measured on plan across joists.</p>	<p>D1 Sizes stated in item descriptions for <i>carpentry and joinery</i> shall be nominal sizes unless otherwise stated.</p> <p>D2 Ceiling joists shall be classed as <i>pitched roofs</i> where they are associated with pitched roofs.</p> <p>D3 Timber and other manufactured boards shall be classed as <i>sheat boarding</i>.</p> <p>D4 <i>Boarding and insulation</i> shall be classified according to their angle of inclination as follows:</p> <table border="1"> <thead> <tr> <th>Class</th> <th>Angle of inclination to the vertical</th> </tr> </thead> <tbody> <tr> <td>Floors</td> <td>75°-90°</td> </tr> <tr> <td>Sloping upper surfaces</td> <td>15°-75°</td> </tr> <tr> <td>Walls</td> <td>Not exceeding 75°</td> </tr> <tr> <td>Soffits</td> <td>15°-90°</td> </tr> </tbody> </table> <p>Surfaces of columns shall be classed as <i>walls</i>. Surfaces of beams shall be classed as <i>soffits</i>.</p>	Class	Angle of inclination to the vertical	Floors	75°-90°	Sloping upper surfaces	15°-75°	Walls	Not exceeding 75°	Soffits	15°-90°	<p>C1 Items for <i>carpentry and joinery</i> shall be deemed to include fixing, boring, cutting, jointing, supply of fixing components and drilling or cutting associated work.</p>	<p>A1 Item descriptions for <i>carpentry and joinery</i> shall state the materials used and identify whether they are <i>sawn</i> or <i>wrought</i> and any treatment, selection or protection for subsequent treatment.</p> <p>A2 Item descriptions shall state the nominal thickness of <i>boarding</i>.</p> <p>A3 The width of <i>boarding</i> shall be stated in item descriptions in 100 mm stages where it does not exceed 300 mm.</p> <p>A4 Item descriptions for <i>structural and carcassing timber</i> (other than <i>cleats, rafters and trusses</i>) and <i>miscellaneous joinery</i> shall state the overall nominal gross cross-sectional dimensions and the number of different cross-section shapes where there are more than one.</p> <p>A5 Item descriptions shall identify applied laminates and coverings.</p> <p>A6 Item descriptions shall identify the shape, size and limits of <i>stairs and walkways</i> and <i>units and fittings</i>.</p>
Class	Angle of inclination to the vertical												
Floors	75°-90°												
Sloping upper surfaces	15°-75°												
Walls	Not exceeding 75°												
Soffits	15°-90°												
			<p>A7 Item descriptions for <i>insulation</i> shall state the materials and their overall nominal thickness.</p>										
		<p>C2 Items for <i>windows, doors and glazing</i> shall be deemed to include fixing, supply of fixing components and drilling or cutting of associated work.</p>	<p>A8 Item descriptions for <i>windows, doors and glazing</i> (Z 3 1-3 *) shall identify the shape, size and limits of the work.</p>										
			<p>A9 Materials shall be stated in item descriptions for <i>ironmongery</i>.</p>										

NOTE
Windows and their *sub-frames* (Z 3 1-3 1-2), *doors* and their *frames or lining sets* (Z 3 1-3 3-4) and the associated *ironmongery* may be included in the measurement of *doors* or *windows* provided that the work included is identified in item descriptions in accordance with paragraph 5.12 and the appropriate statements are given in the Preamble in accordance with paragraph 5.4.

CLASS Z

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
3 Windows, doors and glazing (continued)	5 Glazing	1 Glass 2 Glass in large panes 3 Special glass 4 Hermetically sealed units 5 Mirrors
	6 Patent glazing m ²	1 Roofs 2 Opening lights 3 Vertical surfaces
4 Surface finishes, linings and partitions	1 In situ finishes, beds and backings 2 Tiles 3 Flexible sheet coverings 4 Dry partitions and linings	1 Floors 2 Sloping upper surfaces 3 Walls 4 Soffits 5 Surfaces of width not exceeding 300 mm 6 Surfaces of width 300 mm-1 m
	5 Suspended ceilings	1 Depth of suspension: not exceeding 150 mm 150-500 mm exceeding 500 mm 4 Bulkheads 5 Access panels 6 Fittings
	6 Raised access floors m ²	
	7 Proprietary system partitions	1 Solid 2 Fully glazed 3 Partially glazed 4 Door units
	8 Framed panel cubicle sets nr	

CLASS Z

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES										
	<p>D5 Panes which exceed 4 m² shall be classed as <i>large panes</i>.</p> <p>D6 The following materials used in glazing shall be classed as <i>special glass</i>:</p> <p>(a) glass whose thickness exceeds 10 mm</p> <p>(b) non-rectangular panes of glass</p> <p>(c) toughened, laminated, solar control and other speciality glass</p> <p>(d) acrylic, polycarbonate and similar materials.</p>	<p>C2 Items for <i>windows, doors and glazing</i> shall be deemed to include fixing, supply of fixing components and drilling or cutting of associated work.</p>	<p>A10 Item descriptions for <i>glazing</i> shall identify the materials, their nominal thicknesses, the method of glazing and the method of securing the glass.</p> <p>A11 Item descriptions shall identify the construction of <i>hermetically sealed units</i>.</p> <p>A12 Item descriptions for <i>special glass, hermetically sealed units and mirrors</i> shall identify the shape and size of panes.</p> <p>A13 Item descriptions for <i>glazing</i> shall identify work which is curved.</p>										
<p>M2 No deduction from the areas measured shall be made for holes and openings each not exceeding 0.5 m² in area.</p> <p>M4 The areas measured for <i>patent glazing</i> shall include areas occupied by glazing bars.</p>			<p>A14 Item descriptions shall identify the shape, size and limits of <i>patent glazing</i>.</p> <p>A15 Incidental metalwork supporting <i>patent glazing</i> shall be identified in item descriptions.</p> <p>A16 Item descriptions for <i>patent glazing</i> shall identify work which is curved.</p>										
<p>M2 No deduction from the areas measured shall be made for holes and openings each not exceeding 0.5 m² in area.</p> <p>M5 The length measured for <i>proprietary system partitions</i> shall exclude the length of voids which extend to the full height of the partition.</p>	<p>D7 <i>Surface finishes, linings and partitions</i> (Z 4 1-4 *) exceeding 1 m wide shall be classified according to their angle of inclination as follows:</p> <table border="1"> <thead> <tr> <th>Class</th> <th>Angle of inclination to the vertical</th> </tr> </thead> <tbody> <tr> <td>Floors</td> <td>75°-90°</td> </tr> <tr> <td>Sloping upper surfaces</td> <td>15°-75°</td> </tr> <tr> <td>Walls</td> <td>Not exceeding 15°</td> </tr> <tr> <td>Soffits</td> <td>15°-30°</td> </tr> </tbody> </table> <p>Surface of columns exceeding 1 m wide shall be classed as <i>walls</i>. Surfaces of beams exceeding 1 m wide shall be classed as <i>soffits</i>.</p>	Class	Angle of inclination to the vertical	Floors	75°-90°	Sloping upper surfaces	15°-75°	Walls	Not exceeding 15°	Soffits	15°-30°	<p>C3 Items for <i>surface finishes, linings and partitions</i> shall be deemed to include fixing, supply of fixing components and drilling or cutting of associated work.</p> <p>C4 Items for <i>surface finishes, linings and partitions</i> shall be deemed to include preparing surfaces, forming joints, mitres, angles, fillets, built-up edges and laying to cambers or falls.</p> <p>C5 Items for <i>surface finishes, linings and partitions</i> shall be deemed to include forming holes, cutting and making good for services.</p> <p>C6 Items for <i>suspended ceilings</i> shall be deemed to include associated primary support systems and edge trims.</p>	<p>A17 The materials, surface finish and finished thickness shall be identified in item descriptions for <i>surface finishes, linings and partitions</i>.</p> <p>A18 Lathing and baseboarding associated with <i>in situ finishes, bed and backings</i> shall be identified in item descriptions.</p> <p>A19 The girth of <i>bulkheads</i> shall be identified in item descriptions.</p> <p>A20 The overall dimensions of <i>access panels and fittings</i> in ceilings, <i>door units</i> in proprietary system partitions and <i>framed panel cubicle sets</i> shall be identified in item descriptions.</p> <p>A21 Item descriptions for <i>suspended ceilings</i> shall state the depth of the suspension where it exceeds 500 mm in stages of 500 mm.</p>
Class	Angle of inclination to the vertical												
Floors	75°-90°												
Sloping upper surfaces	15°-75°												
Walls	Not exceeding 15°												
Soffits	15°-30°												

CLASS Z

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
5 Piped building services	1 Pipework	1 Pipes 2 Fittings 3 Insulation
	2 Equipment nr	1 Boiler plant and ancillaries 2 Convectors and radiators 3 Pumps 4 Cisterns and tanks
	3 Sanitary appliances and fittings nr	
6 Ducted building services	1 Circular ductwork 2 Rectangular ductwork	1 Straight 2 Curved 3 Fittings 4 Insulation
	3 Equipment nr	1 Conditioning and handling units 2 Heaters 3 Fans 4 Filters

CLASS Z

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M6 Lengths of pipes shall be measured along their centre lines and shall include lengths occupied by <i>fittings</i>.</p>	<p>D8 Taps shall be classed as pipe <i>fittings</i>.</p>	<p>C7 Items for <i>piped services systems</i> shall be deemed to include fixing and supply of fixing components.</p> <p>C8 Items for <i>piped services systems</i> shall be deemed to include commissioning.</p>	<p>A22 The location or type of <i>piped building services</i> in each item or group of items shall be stated in item descriptions so that the work included can be identified by reference to the Drawings.</p> <p>A23 The materials, joint types, and nominal bores of <i>pipework</i> shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities. <i>Fittings</i> on pipes of different nominal bores shall be identified by their larger bore.</p> <p>A24 The type of <i>equipment or sanitary appliances and fittings</i> and the materials, size or capacity, and the method of fixing shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities.</p> <p>A25 Traps shall be identified in item descriptions for <i>sanitary appliances and fittings</i>.</p>
<p>M7 Lengths of <i>ducted services systems</i> shall be measured along their centre lines and shall include lengths occupied by <i>fittings</i>.</p>		<p>C9 Items for <i>ducted building services</i> shall be deemed to include fixing and supply of fixing components.</p> <p>C10 Items for <i>ducted building services</i> shall be deemed to include commissioning.</p>	<p>A26 The location or type of <i>ducted building services</i> in each item or group of items shall be stated in item descriptions so that the work included can be identified by reference to the Drawings.</p> <p>A27 The materials, joint types, and size of <i>ductwork</i> shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities. <i>Fittings</i> on ducts of different sizes shall be identified by their largest size.</p> <p>A28 The type of <i>equipment</i> and the materials, size or capacity, and the method of fixing shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities.</p>

NOTE

Taps may be included in item descriptions for *sanitary appliances and fittings* instead of by separate items for pipe *fittings* provided that the work included is identified in item descriptions in accordance with paragraph 5.12 and the appropriate statements are given in the Preamble in accordance with paragraph 5.4.

CLASS Z

FIRST DIVISION	SECOND DIVISION	THIRD DIVISION
7 Cabled building services	1 Cables m	1 Laid or drawn into conduits, trunking or ducts 2 Laid on trays 3 Fixed to surfaces 4 Laid in trenches 5 Suspended
	2 Conduits	1 Plain m 2 Flexible m 3 Box fittings nr
	3 Trunking 4 Busbar trunking 5 Trays	1 Plain m 2 Fittings nr
	6 Earthing and bonding	1 Tapes m 2 Fittings nr
	7 Final circuits nr	1 Cable only 2 Cable and conduit
	8 Equipment and fittings nr	1 Equipment 2 Switches 3 Lighting outlets 4 Sockets

CLASS Z

MEASUREMENT RULES	DEFINITION RULES	COVERAGE RULES	ADDITIONAL DESCRIPTION RULES
<p>M8 Lengths measured for <i>cables</i> shall exclude lengths occupied in sags and tails.</p> <p>M9 Lengths measured for <i>conduits, trunking, busbar, trunking and cable trays</i> shall include lengths occupied by fittings.</p> <p>M10 Lengths measured for <i>cables laid or drawn into conduits, trunking or ducts or laid on trays</i> shall be measured as the length of conduit, trunking, duct or tray.</p>	<p>D9 Simple low voltage power and lighting circuits which loop from distribution boards shall be classed as <i>final circuits</i>.</p>	<p>C11 Items for <i>cabled building services</i> shall be deemed to include determining circuits, terminations and connections, providing draw wires and draw cables, cleaning trunking, ducts and trays and threading cables through sleeves.</p> <p>C12 Items for <i>cabled building services</i> shall be deemed to include fixing and supply of fixing components.</p> <p>C13 Items for <i>cabled building services</i> shall be deemed to include commissioning.</p> <p>C14 Items for <i>conduits</i> shall be deemed to include fittings other than <i>boxed fittings</i>.</p>	<p>A29 The location or type of <i>cabled building services</i> in each item or group of items shall be stated in item descriptions so that the work included can be identified by reference to the Drawings.</p> <p>A30 The materials, size or capacity, and method of fixing shall be identified in item descriptions for <i>cabled building services</i> (Z 7 1-7 +) and reference given to applicable British Standard specifications and specified qualities.</p> <p>A31 The type and size or capacity of <i>equipment and fittings</i> (Z 7 8 +) shall be stated in item descriptions and reference given to applicable British Standard specifications and specified qualities.</p>